



OIL & GAS DEVELOPMENT COMPANY LIMITED
PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD
SCHEDULE OF REQUIREMENT

Material : **TROLLEY MOUNTED DIESEL ENGINE DRIVEN FIRE PUMP**

Due Date:

Tender Enquiry No: **PROC-LE/17551**

Bid Bond Value : RS. 370,000/-

EVALUATION WILL BE CARRIED OUT ON MAIN ITEM

Attachment(if any) : YES

Sr No	Description	Quantity	Make/Brand offered	Unit	Unit Price (PKR) Inclusive Of All Taxes Except GST	Unit Price (PKR) Inclusive of GST	Total Price (PKR) Inclusive of GST	Delivery Period Offered	deviation from Tender Spec. If Any
1	PUMP,FIRE "MERAJ" MODEL 'FP50C',TYPE TROLLEY MOUNTED WITH CANOPY,TANDEM AXEL WITH TOW-HOOK,TYRE 1100X20,DELIVERY 5000 LPM @ 140 PSI,SUCTION 5" X 4" X 2-1/2",COUPLED WITH DIESEL ENGINE "CUMMINS",MODEL 6BTA 5.9,200 HP. OR EQUIVALENT	1		Number					
2	CRITICAL/CONSUMABLE SPARES FOR TWO YEARS OPERATION OF OFFERED FIRE PUMP ALONG WITH ITEMS MENTIONED AT SR.NO.6 OF TERMS AND CONDITIONS.	1		Lot					

Special Note:- The prospective bidders also download the master set of Tender Document

- The prospective bidders may keep in touch with OGDCL web site for downloading the clarifications/amendments (if any) issued by OGDCL.
- I. MATERIAL WILL BE DELIVERED AT KORANGI BASE STORE. II. PAYMENT TERM IS PAYMENT AFTER DELIVERY. III. BID VALIDITY IS 120 DAYS

Discount (if any) shall only be entertained on Schedule of Requirement of Bidding Document (Financial Proposal). If the discount is mentioned elsewhere in the bid, the same shall not be entertained.

Terms & conditions for the procurement of trolley mounted diesel engine driven fire pump.

1. Bidder should be the manufacturer or authorized dealer of the manufacturer of the offered firefighting pump unit. In case bidder is authorized dealer of original equipment manufacturer (OEM), a valid authority letter issued by the OEM in favor of the bidder must be provided with the technical proposal.
2. Manufacturer should have minimum 15 year experience in the field of firefighting equipment manufacturing / supplying (bidder to provide documentary evidence with technical bid in this regard).
3. Fire Pump Unit should be NFPA (National Fire Protection Association) compliant and confirmation with NFPA code should be provided along with the bid.
4. OEM or OEM authorized dealers after sales services / workshops facilities should be available locally in main cities (bidder to provide documentary evidence with the technical bid).
5. Company profile of manufacturer must be provided with the technical bid.
6. The required engine driven trolley mounted fire pump unit should be as per given specs and must be supplied complete in all respects with standard firefighting accessories including suction hoses, delivery hoses, nozzles, couplings, fittings, valves, control / operating panel, gauges etc.
7. Consumable spares for two years operation as recommended by OEM of the offered fire pump to be quoted separately giving part numbers, quantities, unit price and extended price of each item along with following items. The rates shall be as per IPL of the OEM locked for two years.
 - i. 02 No suction hoses each of 5'' x 10 ft length as per suction connection with gun metal couplings.
 - ii. 03 No. delivery hoses each of 2-1/2'' x 100 Ft length with internal nylon rubber lining & external polyurethane coating (minimum working pressure 180 Psi) with compatible gun metal couplings.
 - iii. 02 No. suction strainer (5'') with NRV.
 - iv. 01 No. Compatible basket strainer.
 - v. 03 No. NozzlesOGDCL may increase or decrease the quantity of the offered spares as per its own requirement.
8. Offered firefighting units should be capable to operate and perform at -10 to 55°C ambient temperature.
9. Manufacturer's warranty of offered fire pump/assys/spares against defects in performance, material and workmanship is required to remain valid for the period of 18 months from the date of shipment or 12 months from the date of spares installation whichever comes first and such warranty must be provided with the technical proposal.
10. A list of clients to whom the bidder has supplied such type of fire pumps in last five years must be provided with the technical proposal showing type and quantity of sold fire pumps and mentioning name, e-mail address and phone number of each client.
11. Installation / commissioning / initial operational demonstration of firefighting pumps at rig site will be supplier's responsibility (free of cost).
12. 02 Sets of Operation and maintenance manual, service (workshop) manual, parts manual of engine/pump and operating manual of unit to be provided free of cost along with the firefighting pumps at the time of delivery.
13. Standard tool kit, suction / delivery wrenches will be provided by supplier free of cost & list of tools to be provided with the technical proposal.
14. Delivery period will be 150 days after issuance of purchase order.

Note: Above terms and conditions are integral part of S.o.R (Schedule of Requirement) of the tender enquiry.



OIL & GAS DEVELOPMENT COMPANY LIMITED
PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD
SCHEDULE OF REQUIREMENT

Mandatory Checklist

Please confirm the compliance of the following mandatory information along with the bid(s) (failing which bids(s) will not be accepted)

Documents	To be Attached with the Technical/Financial Bids	Compliance	
		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Original Bid Bond	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Copy of NTN Certificate	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Copy of GST Certificate	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Confirmation that the Firm is appearing on FBR's Active Taxpayer List	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly signed and stamped Annexure-A (Un-priced)	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped Annexure-B	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped Annexure-D	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped Annexure-L on Company's Letterhead	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly signed and stamped Annexure-M on Company's Letterhead	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly signed and stamped Annexure-N on Non-Judicial Stamp Paper duly attested by Notary Public	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped Annexure-A (Priced)	Financial Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped Annexure-C	Financial Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped Annexure-E	Financial Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>