



#### OIL & GAS DEVELOPMENT COMPANY LIMITED PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD SCHEDULE OF REQUIREMENT

#### Material :BATTERIES OF SOLAR POWER SYSTEM INSTALLED AT UCH **WELL SITES**

Due Date:

Tender Enquiry No: PROC-LC/PROD-17666

Bid Bond Value: 600,000/-

**EVALUATION WILL BE CARRIED OUT ON FULL** 

Attachment(if any): YES (04)

r No	Description	Quantity	Make/Brand offered	Unit	Unit Price (PKR) Inclusive Of All Taxes Except GST	Unit Price (PKR) Inclusive of GST	Total Price (PKR) Inclusive of GST	Delivery Period Offered	deviation from Tender Spec. If Any
	SOLAR POWER BATTERIES 12V, VRLA AGM DEEP CYCLE, A.H CAPACITY 205 AH @ 20 HR, DETAIL SPECIFICATION IS ATTACHED AT ANNEXURE-Y	60		Number					
2	SOLAR POWER BATTERIES 2V, A.H CAPACITY 1186 AH @ 20 HR, DETAIL SPECIFICATION IS ATTACHED AT ANNEXURE-Z	180		Number					

Special Note: The prospective bidders also download the master set of Tender Document

- The prospective bidders may keep in touch with OGDCL web site for downloading the clarifications/amendments (if any) issued by OGDCL. BID VALIDITY 120 DAYS AFTER TECHNICAL BID OPENING DELIVERY PERIOD: 60 DAYS AFTER LPO ON UCH GAS FIELD, 100%

PAYMENT AFTER DELIVERY AND INSPECTION

Discount (if any) shall only be entertained on Schedule of Requirement of Bidding Document (Financial Proposal). If the discount is mentioned elsewhere in the bid, the same shall not be entertained.



# OIL & GAS DEVELOPMENT COMPANY LIMITED PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD SCHEDULE OF REQUIREMENT

#### Mandatory Checklist

Please confirm the compliance of the following mandatory information along with the bid(s) (failing which bids(s) will not be accepted)

Documents	To be Attached with the Technical/Financial Bids	(s) (failing which bids(s) will not be a Compliance		
Original Bid Bond	Technical Bid	- V	No 🗆	
Copy of NTN Certificate		Yes	100	
Copy of GST Certificate	Technical Bid	Yes	No 🗆	
	Technical Bid	Yes	No 🗆	
Confirmation that the Firm is appearing on FBR's Active Taxpayer ist	Technical Bid	Yes 🗆	No 🗆	
Ouly signed and stamped Annexure-A (Un-priced)	Technical Bid	Yes 🗆	No 🗆	
Ouly filled, signed and stamped Annexure-B	Technical Bid	Yes 🗆	No 🗆	
Ouly filled, signed and stamped Annexure-D	Technical Bid	Yes 🗆	No 🗆	
ouly filled, signed and stamped Annexure-L on Company's etterhead	Technical Bid	Yes	No $\square$	
ouly signed and stamped Annexure-M on Company's Letterhead	Technical Bid	Yes		
uly signed and stamped Annexure-N on Non-Judicial Stamp aper duly attested by Notary Public	T-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1		No	
uly filled, signed and stamped Annexure-A (Priced)	Technical Bid	Yes	No 🗆	
	Financial Bid	Yes	No 🗆	
uly filled, signed and stamped Annexure-C	Financial Bid	Yes		
uly filled, signed and stamped Annexure-E	Financial Bid	Yes	No 🗆	





#### OIL & GAS DEVELOPMENT COMPANY LIMITED PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD SCHEDULE OF REQUIREMENT

For the Vendors/Contractors who opt to submit Bank Draft/Call Deposit/Pay order against Bid Bond/Performance Bond, our Accounts Department has finalized an arrangement for online payment to such Vendors/Contractors, which will be processed through (IBFT & LFT) for which following information is required:

i.	IBAN No. (International Bank Account Number 24 Digits)	
ii.	Vendor Name as per Title of their Bank Account	
iii.	Contact No.of Company's CEO/ Owner (Mobile & Landline)	
iv.	Bank Name.	
v.	Bank Branch Name and Code	

Name,	Sign and	Stamp of	the authorized	official of the B	idder(s) _	
-------	----------	----------	----------------	-------------------	------------	--

		1
IL	11-	-1
	42	

4000	Annexure-Y	DETAILED SPECIFICATION SHEET
•	No and	BATTERIES FOR UCH-I WELL SITES SOLAR POWER SYSTEM
Gei	neral	
1	Battery Type	VRLA AGM Deep Cycle/ Non-Spillable / Maintenance-Free batteries
2	Material Type	Polypropylene
3	Life Expactancy Standard	IEC 61427
4	Test & Design Compliance	BCI, DIN, BS & IEC Standards
5	Battery Life	5+ years
6	Warranty/ Guarantee	Standard
7	Quantity Required	Sixty (60)
Phy	ysical Specification	
8	Terminal Type	M8/LT
9	Weight	59 Kg
10	Length	14.97 Inches
11	Width	6.94 Inches
12	Height	14.07 Inches
Ele	ctrical Specifications	
13	Voltage	12 V
_	Capacity	205Ah @ 20Hr
	Internal Resistance	$4.5~\text{m}\Omega$
20000000	Short Circuit Current	2097 amps
Do	cumentation	
17	Installation/ O & M Manuals	Yes
18	Data/ Specification Sheet	Yes
		ier Minimum 5 years for same type of material

### Delivery Notes:

- \* Batteries should be delivered with most recent date of manufacturing i.e. it should be fresh stock.
- \* Supplier/ Bidder should mention the manufacturing date on each battery.





#### Annexure-Z

## DETAILED SPECIFICATION SHEET BATTERIES FOR UCH-II WELL SITES SOLAR POWER SYSTEM

"(	9 03.	DATTERIES FOR OCH-II WELL SITES SOLAR POWER SYSTEM
Gei	neral	
1	Battery Type	Flooded 2V Photovoltaic Battery, UL listed
2	Material Type	Microphorus Polypropylene [Separators], Molded High impact Polypropylene [Jar/Cover]
3	Cycle Life	1500 cycles @ 80% DOD, 4000@ 20% DOD
4	Self Discharge	4% per month
5	Battery Life	10+ years
6	Warranty/ Guarantee	Standard
7	Quantity Required	One Hundred Eighty (180)
Phy	sical Specification	
8	Weight	83 Kg
9	Length	8.25 Inches
10	Width	6.5 Inches
11	Height	31.375 Inches with flat cover
Elec	ctrical Specifications	
12	Voltage	2 V nominal
13	Capacity	1186 Ah @ 20Hr [at 25°C]
14	Full Charge Specific Gravity	1.245-1.255
15	Finish rate	50 amps
Do	cumentation	
16	Installation/ O & M Manuals	Yes
17	Data/ specification sheet	Yes
18	Required Manufacturing Experier	Minimum 5 years for same type of material

#### **Delivery Notes:**

- \* Batteries should be delivered with most recent date of manufacturing i.e. it should be fresh stock.
- \* Supplier/ Bidder should mention the manufacturing date on each battery.