



**OIL & GAS DEVELOPMENT COMPANY LIMITED**  
**PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD**  
**SCHEDULE OF REQUIREMENT**

P-115

Material : **MEDIUM VOLTAGE SWITCHGEAR**

**Due Date:**

Tender Enquiry No: **PROC-LD/PT/P&P/18140**

Bid Bond Value : 46000

Attachment(if any) : YES

EVALUATION WILL BE CARRIED OUT ON FULL

| Sr No | Description   | Quantity | Make/Brand offered | Unit   | Unit Price (PKR) Inclusive Of All Taxes Except GST | Unit Price (PKR) Inclusive of GST | Total Price (PKR) Inclusive of GST | Delivery Period Offered | deviation from Tender Spec. If Any |
|-------|---|----------|--------------------|--------|--|-----------------------------------|------------------------------------|-------------------------|------------------------------------|
| 1     | Supply with Installation, Commissioning, Function and Load Test of MV Switchgear comprising of VCB (6.6 KV, 630 Amp), Feeder Protection Relay, CTs, PTs ( Details See Attached) and as per details attached ( Schedule of Requirement). | 1        |                    | Number |  |                                   |                                    |                         |                                    |

**Special Note:** The prospective bidders also download the master set of Tender Document

- The prospective bidders may keep in touch with OGDCL web site for downloading the clarifications/amendments (if any) issued by OGDCL.
- BID VALIDITY: 120 DAYS AFTER TECHNICAL BID OPENING. DELIVERY LOCATION: UCH GAS PLANT, DELIVERY PERIOD: 120 DAYS AFTER ISSUANCE OF LPO, PAYMENT TERM: 100% AFTER DELIVERY, INSTALLATION & COMMISSIONING.

ATTACHMENT FOR INDENT NO. UCH-5414  
FOR ALL THE ITEMS.

( including CT Test Block, Energy Analyzer, Digital Ammeter, Selector Switch and Other Accessories)

1. BIDDER TO CONFIRM THAT ALL ITEMS ARE BRAND NEW WITH STANDARD WARRANTY/GARRANTY.
2. BIIDER TO SUPPLY THE ITEMS IN STANDARD PACLING.
3. Installation, Commissioning, Function and Load Test of MV Switchgear (6.6KV, 630 Amp) mentioned in SOR. Power Cable Termination at existing MV Bus and MV Switchgear End.
4. DETAILS OF SCHEDULE OF REQUIREMENT ARE ATTACHED AT FLAG-A

P-2/5

| Sr. No                                  | Description   | QTY         | Unit                 |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
|---|---|-------------|----------------------|---|--|---------|--|---------------------------|--|---------------------------------------|---|-------------------------|--|---------------|--|-----------------|--|--|---|----------------|--|-------------------------|--|------------------|--|----------------|--|-------------|---|-------------|--|------------|---|------------------|---|-----------------------|---|--|--|
| 01                                      | Schedule of Requirement for <b>Supply of Medium Voltage Switchgear Panel (6.6KV, 630A)</b>  | 01          | No                   |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
|   | <table border="1"> <thead> <tr> <th data-bbox="105 365 399 393">Switch Gear</th> <th data-bbox="399 365 1085 393">Basic Technical Data</th> </tr> </thead> <tbody> <tr> <td data-bbox="105 393 399 741">Vacuum Circuit Breaker<br/>Draw Out Type</td> <td data-bbox="399 393 1085 741"> <ul style="list-style-type: none"> <li>• 3 Pole, Rated Current: 630A</li> <li>• Rated Voltage: 12KV @50/60HZ</li> <li>• Rated short circuit Making current 80KA.</li> <li>• Rated Short Circuit Breaking Current: 31.5KA.</li> <li>• Rated short circuit Duration 3 Sec.</li> <li>• Rated Insulation Level (BIL) 75KV or 95KV</li> <li>• Motor Drive: 230VAC.</li> <li>• Closing Coil: 230VAC.</li> <li>• Shunt Trip Coil: 230VAC.</li> <li>• UVT Coil: 230VAC</li> <li>• Make: ABB Italy, Schneider France</li> </ul> </td> </tr> <tr> <td data-bbox="105 741 399 797">Bus Bar</td> <td data-bbox="399 741 1085 797"> <ul style="list-style-type: none"> <li>• 630Amp, 75KV BIL, Copper, Tin Coated, Short Circuit Rating 25KA at @ 1-Sec, Size : 1 x 80 x 10mm</li> </ul> </td> </tr> <tr> <td data-bbox="105 797 399 853">Earthing switch<br/>3 Pole</td> <td data-bbox="399 797 1085 853"> <ul style="list-style-type: none"> <li>• Rated Voltage :12KV</li> <li>• Rated Short Time Current 25KA @ 1-Sec</li> </ul> </td> </tr> <tr> <td data-bbox="105 853 399 1013">Current Transformer<br/>1 Pole, 03 Nos</td> <td data-bbox="399 853 1085 1013"> <ul style="list-style-type: none"> <li>• Ratio 1200: 600A/1A: 1A. or 5A</li> <li>• Protection Core: 15VA.</li> <li>• Metering Core: 15VA.</li> <li>• BIL: 12KV, 28KV, 75KV.</li> <li>• STC 18.4KA@3Sec, Frequency : 50Hz</li> </ul> </td> </tr> <tr> <td data-bbox="105 1013 399 1078">Feeder Protection Relay</td> <td data-bbox="399 1013 1085 1078"> <ul style="list-style-type: none"> <li>• Multi-Function O/C, G/F, S/C, U/V Protection Relay (Make: GE Multilin, Schneider Micom, ABB)</li> </ul> </td> </tr> <tr> <td data-bbox="105 1078 399 1116">PT Test Block</td> <td data-bbox="399 1078 1085 1116"> <ul style="list-style-type: none"> <li>• Type: MMLG01, Make: GE or Equivalent</li> </ul> </td> </tr> <tr> <td data-bbox="105 1116 399 1200">Energy Analyzer</td> <td data-bbox="399 1116 1085 1200"> <ul style="list-style-type: none"> <li>• Type: PM 750</li> <li>• PT Input: --/220VAC, CT Input: --/1A or 5A</li> <li>• Supply : 230VAC, Make: Schneider or Equivalent</li> </ul> </td> </tr> <tr> <td data-bbox="105 1200 399 1322">Voltage Transformer,<br/>1 Pole, 03 Nos</td> <td data-bbox="399 1200 1085 1322"> <ul style="list-style-type: none"> <li>• Ratio 6.6KV: v3 / 220V: v3</li> <li>• Burdon: 100VA Class 0.5</li> <li>• Insulation Level: 12/36/95KV</li> <li>• Frequency : 50HZ</li> </ul> </td> </tr> <tr> <td data-bbox="105 1322 399 1388">Ammeter Module</td> <td data-bbox="399 1322 1085 1388"> <ul style="list-style-type: none"> <li>• Measuring input 0...1A.</li> <li>• Input frequency 50HZ, Aux supply 230VAC</li> </ul> </td> </tr> <tr> <td data-bbox="105 1388 399 1416">Ammeter Selector Switch</td> <td data-bbox="399 1388 1085 1416"> <ul style="list-style-type: none"> <li>• 4 Position</li> </ul> </td> </tr> <tr> <td data-bbox="105 1416 399 1444">Indication Lamps</td> <td data-bbox="399 1416 1085 1444"> <ul style="list-style-type: none"> <li>• ON, OFF, TRIP, Test Position, 220VAC</li> </ul> </td> </tr> <tr> <td data-bbox="105 1444 399 1472">Emergency Stop</td> <td data-bbox="399 1444 1085 1472"> <ul style="list-style-type: none"> <li>• ON, OFF, Lamp Test, Emergency Stop</li> </ul> </td> </tr> <tr> <td data-bbox="105 1472 399 1510">Panel Light</td> <td data-bbox="399 1472 1085 1510"> <ul style="list-style-type: none"> <li>• 60W, 220VAC, 50Hz</li> </ul> </td> </tr> <tr> <td data-bbox="105 1510 399 1566">Accessories</td> <td data-bbox="399 1510 1085 1566"> <ul style="list-style-type: none"> <li>• MCBs, Auxiliary Contacts, Relays, Terminals as per Requirement</li> </ul> </td> </tr> <tr> <td data-bbox="105 1566 399 1688">Panel Type</td> <td data-bbox="399 1566 1085 1688"> <ul style="list-style-type: none"> <li>• 2.3 mm thick Indoor Type Floor Mounting Free Standing Design with Copper Bus Bar</li> <li>• Fully wired complete cubical housing which will be metal clad sheet fabricated totally enclosed</li> </ul> </td> </tr> <tr> <td data-bbox="105 1688 399 1754">Panel Dimensions</td> <td data-bbox="399 1688 1085 1754"> <ul style="list-style-type: none"> <li>• H x W x D</li> <li>• 2200 mm x 690 mm x 1370 mm</li> </ul> </td> </tr> <tr> <td data-bbox="105 1754 399 1838">Cable Termination Kit</td> <td data-bbox="399 1754 1085 1838"> <ul style="list-style-type: none"> <li>• For MV Power Cable, 300mm, Single Core, 3 Phase Termination at MV Bus Bar and MV Switch gear end. (1x 3 connections at both sides).</li> </ul> </td> </tr> </tbody> </table> | Switch Gear | Basic Technical Data | Vacuum Circuit Breaker<br>Draw Out Type | <ul style="list-style-type: none"> <li>• 3 Pole, Rated Current: 630A</li> <li>• Rated Voltage: 12KV @50/60HZ</li> <li>• Rated short circuit Making current 80KA.</li> <li>• Rated Short Circuit Breaking Current: 31.5KA.</li> <li>• Rated short circuit Duration 3 Sec.</li> <li>• Rated Insulation Level (BIL) 75KV or 95KV</li> <li>• Motor Drive: 230VAC.</li> <li>• Closing Coil: 230VAC.</li> <li>• Shunt Trip Coil: 230VAC.</li> <li>• UVT Coil: 230VAC</li> <li>• Make: ABB Italy, Schneider France</li> </ul> | Bus Bar | <ul style="list-style-type: none"> <li>• 630Amp, 75KV BIL, Copper, Tin Coated, Short Circuit Rating 25KA at @ 1-Sec, Size : 1 x 80 x 10mm</li> </ul> | Earthing switch<br>3 Pole | <ul style="list-style-type: none"> <li>• Rated Voltage :12KV</li> <li>• Rated Short Time Current 25KA @ 1-Sec</li> </ul> | Current Transformer<br>1 Pole, 03 Nos | <ul style="list-style-type: none"> <li>• Ratio 1200: 600A/1A: 1A. or 5A</li> <li>• Protection Core: 15VA.</li> <li>• Metering Core: 15VA.</li> <li>• BIL: 12KV, 28KV, 75KV.</li> <li>• STC 18.4KA@3Sec, Frequency : 50Hz</li> </ul> | Feeder Protection Relay | <ul style="list-style-type: none"> <li>• Multi-Function O/C, G/F, S/C, U/V Protection Relay (Make: GE Multilin, Schneider Micom, ABB)</li> </ul> | PT Test Block | <ul style="list-style-type: none"> <li>• Type: MMLG01, Make: GE or Equivalent</li> </ul> | Energy Analyzer | <ul style="list-style-type: none"> <li>• Type: PM 750</li> <li>• PT Input: --/220VAC, CT Input: --/1A or 5A</li> <li>• Supply : 230VAC, Make: Schneider or Equivalent</li> </ul> | Voltage Transformer,<br>1 Pole, 03 Nos | <ul style="list-style-type: none"> <li>• Ratio 6.6KV: v3 / 220V: v3</li> <li>• Burdon: 100VA Class 0.5</li> <li>• Insulation Level: 12/36/95KV</li> <li>• Frequency : 50HZ</li> </ul> | Ammeter Module | <ul style="list-style-type: none"> <li>• Measuring input 0...1A.</li> <li>• Input frequency 50HZ, Aux supply 230VAC</li> </ul> | Ammeter Selector Switch | <ul style="list-style-type: none"> <li>• 4 Position</li> </ul> | Indication Lamps | <ul style="list-style-type: none"> <li>• ON, OFF, TRIP, Test Position, 220VAC</li> </ul> | Emergency Stop | <ul style="list-style-type: none"> <li>• ON, OFF, Lamp Test, Emergency Stop</li> </ul> | Panel Light | <ul style="list-style-type: none"> <li>• 60W, 220VAC, 50Hz</li> </ul> | Accessories | <ul style="list-style-type: none"> <li>• MCBs, Auxiliary Contacts, Relays, Terminals as per Requirement</li> </ul> | Panel Type | <ul style="list-style-type: none"> <li>• 2.3 mm thick Indoor Type Floor Mounting Free Standing Design with Copper Bus Bar</li> <li>• Fully wired complete cubical housing which will be metal clad sheet fabricated totally enclosed</li> </ul> | Panel Dimensions | <ul style="list-style-type: none"> <li>• H x W x D</li> <li>• 2200 mm x 690 mm x 1370 mm</li> </ul> | Cable Termination Kit | <ul style="list-style-type: none"> <li>• For MV Power Cable, 300mm, Single Core, 3 Phase Termination at MV Bus Bar and MV Switch gear end. (1x 3 connections at both sides).</li> </ul> | Fully Wired and Complete in all Respects |  |
| Switch Gear                             | Basic Technical Data  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Vacuum Circuit Breaker<br>Draw Out Type | <ul style="list-style-type: none"> <li>• 3 Pole, Rated Current: 630A</li> <li>• Rated Voltage: 12KV @50/60HZ</li> <li>• Rated short circuit Making current 80KA.</li> <li>• Rated Short Circuit Breaking Current: 31.5KA.</li> <li>• Rated short circuit Duration 3 Sec.</li> <li>• Rated Insulation Level (BIL) 75KV or 95KV</li> <li>• Motor Drive: 230VAC.</li> <li>• Closing Coil: 230VAC.</li> <li>• Shunt Trip Coil: 230VAC.</li> <li>• UVT Coil: 230VAC</li> <li>• Make: ABB Italy, Schneider France</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Bus Bar                                 | <ul style="list-style-type: none"> <li>• 630Amp, 75KV BIL, Copper, Tin Coated, Short Circuit Rating 25KA at @ 1-Sec, Size : 1 x 80 x 10mm</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Earthing switch<br>3 Pole               | <ul style="list-style-type: none"> <li>• Rated Voltage :12KV</li> <li>• Rated Short Time Current 25KA @ 1-Sec</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Current Transformer<br>1 Pole, 03 Nos   | <ul style="list-style-type: none"> <li>• Ratio 1200: 600A/1A: 1A. or 5A</li> <li>• Protection Core: 15VA.</li> <li>• Metering Core: 15VA.</li> <li>• BIL: 12KV, 28KV, 75KV.</li> <li>• STC 18.4KA@3Sec, Frequency : 50Hz</li> </ul>   |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Feeder Protection Relay                 | <ul style="list-style-type: none"> <li>• Multi-Function O/C, G/F, S/C, U/V Protection Relay (Make: GE Multilin, Schneider Micom, ABB)</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| PT Test Block                           | <ul style="list-style-type: none"> <li>• Type: MMLG01, Make: GE or Equivalent</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Energy Analyzer                         | <ul style="list-style-type: none"> <li>• Type: PM 750</li> <li>• PT Input: --/220VAC, CT Input: --/1A or 5A</li> <li>• Supply : 230VAC, Make: Schneider or Equivalent</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Voltage Transformer,<br>1 Pole, 03 Nos  | <ul style="list-style-type: none"> <li>• Ratio 6.6KV: v3 / 220V: v3</li> <li>• Burdon: 100VA Class 0.5</li> <li>• Insulation Level: 12/36/95KV</li> <li>• Frequency : 50HZ</li> </ul>   |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Ammeter Module                          | <ul style="list-style-type: none"> <li>• Measuring input 0...1A.</li> <li>• Input frequency 50HZ, Aux supply 230VAC</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Ammeter Selector Switch                 | <ul style="list-style-type: none"> <li>• 4 Position</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Indication Lamps                        | <ul style="list-style-type: none"> <li>• ON, OFF, TRIP, Test Position, 220VAC</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Emergency Stop                          | <ul style="list-style-type: none"> <li>• ON, OFF, Lamp Test, Emergency Stop</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Panel Light                             | <ul style="list-style-type: none"> <li>• 60W, 220VAC, 50Hz</li> </ul>   |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Accessories                             | <ul style="list-style-type: none"> <li>• MCBs, Auxiliary Contacts, Relays, Terminals as per Requirement</li> </ul>  |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Panel Type                              | <ul style="list-style-type: none"> <li>• 2.3 mm thick Indoor Type Floor Mounting Free Standing Design with Copper Bus Bar</li> <li>• Fully wired complete cubical housing which will be metal clad sheet fabricated totally enclosed</li> </ul>   |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Panel Dimensions                        | <ul style="list-style-type: none"> <li>• H x W x D</li> <li>• 2200 mm x 690 mm x 1370 mm</li> </ul>   |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |
| Cable Termination Kit                   | <ul style="list-style-type: none"> <li>• For MV Power Cable, 300mm, Single Core, 3 Phase Termination at MV Bus Bar and MV Switch gear end. (1x 3 connections at both sides).</li> </ul>   |             |                      |   |  |         |  |                           |  |                                       |   |                         |  |               |  |                 |  |  |   |                |  |                         |  |                  |  |                |  |             |   |             |  |            |   |                  |   |                       |   |  |  |



**OIL & GAS DEVELOPMENT COMPANY LIMITED**  
**PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD**  
**SCHEDULE OF REQUIREMENT**

P-4/5

**Mandatory Checklist**

Please confirm the compliance of the following mandatory information along with the bid(s) (failing which bids(s) will not be accepted).

| Documents  | To be Attached with the Technical/Financial Bids | Compliance                   |                             |
|--|--|------------------------------|-----------------------------|
|  |  | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Original Bid Bond  | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Copy of NTN Certificate  | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Copy of GST Certificate  | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Confirmation that the Firm is appearing on FBR's Active Taxpayer List                                | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly signed and stamped <b>Annexure-A (Un-priced)</b>  | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped <b>Annexure-B</b>  | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped <b>Annexure-D</b>  | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped <b>Annexure-L</b> on Company's Letterhead                            | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly signed and stamped <b>Annexure-M</b> on Company's Letterhead                                    | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly signed and stamped <b>Annexure-N</b> on Non-Judicial Stamp Paper duly attested by Notary Public | Technical Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped <b>Annexure-A (Priced)</b>   | Financial Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped <b>Annexure-C</b>  | Financial Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped <b>Annexure-E</b>  | Financial Bid                                    | Yes <input type="checkbox"/> | No <input type="checkbox"/> |



**OIL & GAS DEVELOPMENT COMPANY LIMITED  
PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD  
SCHEDULE OF REQUIREMENT**

P-5/5

For the Vendors/Contractors who opt to submit Bank Draft/Call Deposit/Pay order against Bid Bond/Performance Bond, our Accounts Department has finalized an arrangement for online payment to such Vendors/Contractors, which will be processed through (IBFT & LFT) for which following information is required:

|      |  |  |
|------|--|--|
| i.   | IBAN No. (International Bank Account Number 24 Digits) |  |
| ii.  | Vendor Name as per Title of their Bank Account         |  |
| iii. | Contact No.of Company's CEO/ Owner (Mobile & Landline) |  |
| iv.  | Bank Name.   |  |
| v.   | Bank Branch Name and Code                              |  |

Name, Sign and Stamp of the authorized official of the Bidder(s) \_\_\_\_\_