



④/5

OIL & GAS DEVELOPMENT COMPANY LIMITED
PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD
SCHEDULE OF REQUIREMENT

Material : **BATTERIES**

Due Date:

Tender Enquiry No: **PROC-LC/PT/P&P-18397**

Bid Bond Value : RS:- 126,000/=

EVALUATION WILL BE CARRIED OUT ON FULL

Attachment(if any) : YES

| Sr No | Description | Quantity | Make/Brand offered | Unit | Unit Price (PKR) Inclusive Of All Taxes Except GST | Unit Price (PKR) Inclusive of GST | Total Price (PKR) Inclusive of GST | Delivery Period Offered | deviation from Tender Spec. If Any |
|-------|---|----------|--------------------|--------|--|-----------------------------------|------------------------------------|-------------------------|------------------------------------|
| 1 | AGM Type Maintenance Free Battery. See attachment for details. | 69 | | Number | | | | | |
| 2 | Battery A412/20 G5 NGA4120020HS0BA OR Equivalent. See attachment for details. | 12 | | Number | | | | | |
| 3 | Battery Sealed Maintenance Free. See attachment for details. | 2 | | Number | | | | | |
| 4 | Battery WP7-12(28W) OR Equivalent. See attachment for details | 36 | | Number | | | | | |

Special Note: The prospective bidders also download the master set of Tender Document

- The prospective bidders may keep in touch with OGDCL web site for downloading the clarifications/amendments (if any) issued by OGDCL.
- DELIVERY AT KUNNAR PLANT WITHIN 70-84 DAYS. 100% PAYMENT WILL BE MADE AFTER DELIVERY AND INSPECTION. BID VALIDITY MUST BE 180 DAYS AFTER TECHNICAL BID OPENING.



2

OIL & GAS DEVELOPMENT COMPANY LIMITED
PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD
SCHEDULE OF REQUIREMENT

Mandatory Checklist

Please confirm the compliance of the following mandatory information along with the bid(s) (failing which bids(s) will not be accepted)

| Documents | To be Attached with the Technical/Financial Bids | Compliance | |
|--|--|------------------------------|-----------------------------|
| | | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Original Bid Bond | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Copy of NTN Certificate | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Copy of GST Certificate | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Confirmation that the Firm is appearing on FBR's Active Taxpayer List | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly signed and stamped Annexure-A (Un-priced) | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped Annexure-B | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped Annexure-D | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped Annexure-L on Company's Letterhead | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly signed and stamped Annexure-M on Company's Letterhead | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly signed and stamped Annexure-N on Non-Judicial Stamp Paper duly attested by Notary Public | Technical Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped Annexure-A (Priced) | Financial Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped Annexure-C | Financial Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |
| Duly filled, signed and stamped Annexure-E | Financial Bid | Yes <input type="checkbox"/> | No <input type="checkbox"/> |



3

OIL & GAS DEVELOPMENT COMPANY LIMITED
PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD
SCHEDULE OF REQUIREMENT

For the Vendors/Contractors who opt to submit Bank Draft/Call Deposit/Pay order against Bid Bond/Performance Bond, our Accounts Department has finalized an arrangement for online payment to such Vendors/Contractors, which will be processed through (IBFT & LFT) for which following information is required:

| | | |
|------|--|--|
| i. | IBAN No. (International Bank Account Number 24 Digits) | |
| ii. | Vendor Name as per Title of their Bank Account | |
| iii. | Contact No.of Company's CEO/ Owner (Mobile & Landline) | |
| iv. | Bank Name. | |
| v. | Bank Branch Name and Code | |

Name, Sign and Stamp of the authorized official of the Bidder(s) _____

TECHNICAL SPECIFICATIONS

(4)

| SPECIFICATION FOR 69Nos. BATTERIES | | |
|------------------------------------|--|--|
| Sr# | Description | Remarks |
| 1 | Battery | |
| 2 | Type | AGM Type Maintenance Free Battery |
| 3 | Battery Dimension | L= 350mm, W=166mm, H=174mm or SIMILAR to fit 30 Batteries in cabinet size of 800mm(depth)x 1000mm (width)x 1600mm (height) |
| 4 | Floating Charge Voltage (25C) | 13.50~ 13.70V |
| 5 | 20 Hours rate, termination voltage 10.5V (25C) | 69-70AH |
| 6 | 10 Hours rate, termination voltage 10.8V (25C) | 65AH |
| 7 | Approval | UL (Underwriter Laboratories or equivalent) |
| 8 | Design Life | 10~12 Years LONG LIFE,EURO BAT 2015 CLASSIFICATION |
| 9 | Connection Type | F-M6/8. In case M-type battery terminal are offered then terminals should be insulated after connection to avoid corrosion. |
| 10 | Accessories | 1) Battery connection leads 35mm flexible cable or equivalent capacity flexible cable for Series/Parallel Bank configuration. (complete set nuts/bolts/lugs) Insulated boots in case of M-type battery terminal |
| 11 | Battery manufacture date | 2) Battery manufacture date must not be more than 06 MONTHS at the time of delivery at site. |
| 12 | Warranty Period | 12 Months Replacement Warranty |

| SPECIFICATION FOR 12Nos. BATTERIES | | |
|------------------------------------|--|---|
| Sr # | Description | Remarks |
| 1 | Battery | |
| 2 | Type | Batteries GEL Type Maintenance Free |
| 3 | Model | A412/20 G5 NGA4120020HSOBA OR Equivalent |
| 4 | Battery Dimension | L= 176mm, W=167mm, H=126mm |
| 5 | Nominal Voltage | 12 V |
| 6 | 10 Hours rate, termination voltage 1.8V/CELL (20C) | 20AH |
| 7 | Approval | UL (Underwriter Laboratories or equivalent) |
| 8 | Design Life | 12 Years, VERY LONG LIFE AS PER EUROBAT 2015 CLASSIFICATION |
| 9 | Connection Type | G-M5 |
| 10 | Accessories | Battery connection leads or equivalent capacity connection strips (complete set nuts/bolts) |
| 11 | Battery manufacture date | Battery manufacturing date must not be more than 06 MONTHS at the time of delivery at site. |
| 12 | Warranty Period | 12 months Replacement Warranty |

| SPECIFICATION FOR 36 Nos. BATTERIES | | |
|-------------------------------------|--------------------------|---|
| Sr # | Description | Remarks |
| 1 | Battery | |
| 2 | Type | Maintenance Free Sealed Lead Acid Battery |
| 3 | Model | WP7-12(28W) OR Equivalent |
| 4 | Battery Dimension | L= 151mm, W=65mm, H=93.5mm Or equivalent |
| 5 | Nominal Voltage | 12 V |
| 6 | Capacity | 07AH |
| 7 | Design Life | 3-5 Years |
| 8 | Connection Type | Faston F1 |
| 9 | Accessories | Battery connection leads or equivalent capacity connection strips (complete set nuts/bolts) |
| 10 | Battery manufacture date | Battery manufacture date must not be more than 06 MONTHS at the time of delivery at site. |
| 11 | Warranty Period | 12 months Replacement Warranty |

| SPECIFICATION FOR 02 Nos. BATTERIES | | |
|-------------------------------------|--------------------------|---|
| Sr # | Description | Remarks |
| 1 | Battery | |
| 2 | Type | Sealed Maintenance Free Battery |
| 3 | Model | 8D Type, HEAVY DUTY COMMERCIAL TYPE |
| 4 | Nominal Voltage | 12 V |
| 5 | Capacity | >175 AH |
| 6 | CCA | 1300-1400 A |
| 7 | Reserve Capacity | 430 Minutes |
| 8 | Connection Type | SAE |
| 9 | Design Life | 5 years |
| 10 | Accessories | Battery connection leads or equivalent capacity connection strips (complete set nuts/bolts) |
| 11 | Battery manufacture date | Battery manufacture date must not be more than 06 MONTHS at the time of delivery at site. |
| 12 | Warranty Period | 12 months Replacement Warranty |

INSPECTION SCHEDULE:

1. Inspection will be carried out at vendor premises prior to delivery of batteries.
2. Inspection will include following tests:
 - i) Load Test & Ohmic resistance test of sampled batteries in accordance with manufacturer's data & applicable standards.
 - ii) Verification of battery accessories such as connection leads/OEM manufacturing certificates / reports.

OTHER TERMS AND CONDITIONS:

1. Material should be delivered as per above mentioned specifications.
2. All the participating companies should supply material from OEM or authorized distributor, where necessary.
3. After successful delivery of material at site, Bidder will proceed with Supervision of battery bank, which will be installed by OGDC personnel at Kunnar plant.
4. Bidder to confirm that OEM and relevant Factory Manufacturing and Test Certificates of required items will be provided along with the material.
5. The bidder should have the support/technical assistance of OEM.