




KPD-TAY COMPRESSION PROJECT

ISSUED FOR TENDER

0	07-JAN-2022	ISSUED FOR TENDER	JAB	ZHW	AIB	MPM	MAS		
A	29-OCT-2021	ISSUED FOR REVIEW	JAB	ZHW	AIB	MPM	MAS		
REV	DATE	DESCRIPTION	ORIG	CHKD	LE	QA	PM	LPE/TA	
REVISIONS			APPROVAL					OWNER APPROVAL	
<div></div> <div>ENAR Petrotech Services (Pvt.) Limited , 7-B , Sector 7-A , Korangi Industrial Area , Karachi Pakistan</div>		<div>TITLE:</div> <div>SPECIFICATION FOR LV A.C INDUCTION MOTOR</div>							
PROJECT NUMBER 14-0258		DOCUMENT NO:							
		0258 – ELA – 6502 – 0							
		PROJECT CODE	DOC. TYPE		SEQ. NO.		REV		



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 2 of 19
REV: 0
DATE: 07-JAN-2022

CLIENT : OIL & GAS DEVELOPMENT COMPANY LIMITED

PROJECT : KPD-TAY COMPRESSION PROJECT

**SPECIFICATION FOR
LV A.C INDUCTION MOTOR**



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 3 of 19
REV: 0
DATE: 07-JAN-2022

TABLE OF CONTENTS

1. PURPOSE	4
2. REFERENCE STANDARDS & CODES	6
3. SERVICE CONDITIONS	8
4. MAIN DESIGN & CONSTRUCTION REQUIREMENTS	9
5. GUARANTEE	17
6. SHIPPING	18
7. DOCUMENTS	18



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 4 of 19
REV: 0
DATE: 07-JAN-2022

1. PURPOSE

This specification is intended to specify the basic requirements for designing, engineering, selection, sizing, procurement, testing, installation, pre-commissioning and commissioning of LV A.C Squirrel Cage Induction Motors which deemed necessary for defining minimum requirement at preliminary stage and shall not be considered comprehensive and final for procurement. This specification does not absolve the CONTRACTOR from his responsibility of supplying, installing and commissioning suitable LV A.C induction motors complete in all respect. The CONTRACTOR shall develop detailed datasheets, specifications, ITP and installation details based on this specification and submit to the COMPANY/CONSULTANT for approval during detailed engineering stage.

This specification forms a part of other specifications for equipment, which require electric motors. The equipment specification/data sheet shall specify significantly the requisite data w.r.t quantity, type, rating, speed, coupling arrangement, area classification and other special requirements, if any.

The offered Low Voltage A.C Squirrel Cage Induction Motors shall comply with the “*Reference Standards and Codes*”. Where the manufacturer’s standards differ from other supplementary requirements of this specification, details shall be submitted to the COMPANY/CONSULTANT for approval.

In case discrepancies are found between this specification and other documents, COMPANY/CONSULTANT shall be referred for correct interpretation.

1.1. Definition

Where used in this specification, the following terms shall have the meanings indicated below unless otherwise clearly indicated by context of their use.

COMPANY—Oil & Gas Development Company Limited (OGDCL).

CONCESSION REQUEST - A deviation requested by the CONTRACTOR or VENDOR, usually after receiving the contract package or purchase order. Often, it refers to an authorization to use, repair, recondition, reclaim, or release materials, components or equipment already in progress or completely manufactured but which does not meet or comply with COMPANY/CONSULTANT requirements. A Concession Request is subject to COMPANY/CONSULTANT approval.

CONTRACTOR - The party which carries out all or part of the design engineering, procurement, construction and commissioning or management of the project.

DRAWINGS - Drawings provided by the CONTRACTOR/VENDOR.

SUPPLIER/MANUFACTURER - The party which manufactures and/or supplies the material/equipment, and provides technical documents/drawings and services to perform the duties specified by the COMPANY/CONTRACTOR.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 5 of 19
REV: 0
DATE: 07-JAN-2022

PROJECT – KPD-TAY Compression Project.

1.2. Errors & Omissions

- The review and comment by COMPANY/CONSULTANT of any the CONTRACTOR's/VENDOR's drawings, procedures or documents shall only indicate acceptance of general requirements and shall not relieve the CONTRACTOR/VENDOR of its obligations to comply with the requirements of this specification and other related parts of the Contract Documents.
- Any errors or omissions noted by the CONTRACTOR/VENDOR in this Specification shall be immediately brought to the attention of COMPANY/CONSULTANT.

1.3. Deviations

- All deviations to this Specification, other related specifications or attachments shall be brought to the knowledge of COMPANY/CONSULTANT as a section in the bid. All deviations made during the procurement, design, manufacturing, testing and inspection shall be with written approval of COMPANY/CONSULTANT prior to execution of Work. Such deviations shall be shown in the documentation prepared by the CONTRACTOR/VENDOR.

1.4. Conflicting Requirement

- In the event of any conflict, inconsistency or ambiguity between the CONTRACTOR's/VENDOR's scope of work, this Specification, National Codes and Standards, and referenced in the Project Specification or any other documents, the CONTRACTOR/VENDOR shall refer to COMPANY/CONSULTANT whose decision shall prevail.

1.5. Reporting Procedure

- A reporting and documentation system shall be agreed between the CONTRACTOR/VENDOR and COMPANY/ CONSULTANT for the status of procurement, design, manufacturing, inspection, testing and shipment of the equipment/material to be supplied under this specification. The CONTRACTOR/VENDOR shall provide reports and summaries for production performance and testing operations in conformance with a manufacturing schedule approved by COMPANY/CONSULTANT.
- Daily, weekly, monthly and run summaries of all major aspects of the production process shall be provided as reports to COMPANY/CONSULTANT.

1.6. Third Party Inspection:

- In addition to the inspection and witnessing of tests by the inspectors to be appointed by the COMPANY/CONSULTANT during the manufacturing and shipment of the equipment/material, COMPANY/CONSULTANT may appoint a third party or its own inspector for witnessing of the inspection and tests to be carried out at VENDOR's facility under this specification.
 - Information w.r.t inspection and testing purposes as per applied reference Standards and Codes shall be submitted to COMPANY/CONSULTANT.
-



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 6 of 19
REV: 0
DATE: 07-JAN-2022

1.7. Unit Responsibility

- The CONTRACTOR/VENDOR shall be responsible for the complete design, materials, construction, supply, inspection and testing, packing, delivery and performance of Low Voltage A.C Squirrel Cage Induction Motors including full compliance with all applicable design codes and standards, including those listed in "Section-2" of this document and the requirements of the certifying authority, if applicable. The CONTRACTOR/VENDOR shall handle and expedite drawings and data, and supervise and coordinate all inspection and testing.
- The CONTRACTOR/VENDOR shall guarantee that all material and parts included in construction of the specified Low Voltage LV A.C Squirrel Cage Induction Motors shall be new, unused and of the required/ specified grade.

1.8. Documentation

- Documents, calculation/data sheets, technical details, etc., to be submitted to the COMPANY/CONSULTANT shall be in English Language.
- Unless otherwise specified, the metric units shall be used in documents and drawings by the CONTRACTOR/VENDOR.
- The form of drawings and documents may be as per the CONTRACTOR/VENDOR's Standards. However, the format of the data sheet will be submitted to COMPANY/CONSULTANT for approval.
- Variations from or additions to this specification shall be called to the attention of the COMPANY/CONSULTANT and approved in writing by the COMPANY/CONSULTANT prior to starting manufacturing.
- Comments made by COMPANY/CONSULTANT on drawing/technical details submittal shall not relieve the CONTRACTOR/VENDOR of any responsibility in meeting the requirements of the specifications.
- Such comments shall not be construed as permission to deviate from requirements of the Purchase Order unless specific and mutual agreement is reached and confirmed in writing.
- The CONTRACTOR/VENDOR shall notify the COMPANY/CONSULTANT of any apparent conflict between this specification, the related data sheets, the Standards & Codes and any other specification noted herein. Resolution and or interpretation precedence shall be obtained from the COMPANY/CONSULTANT in writing before proceeding with the design manufacture.

2. REFERENCE STANDARDS & CODES

The equipment and material selection w.r.t Low Voltage A.C Squirrel Cage Induction Motor's design, manufacturing, testing and inspection supplied by the CONTRACTOR/VENDOR shall



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 7 of 19
REV: 0
DATE: 07-JAN-2022

comply with this Specification; and material selection shall confirm to the relevant and latest version of the following reference Standards and Codes.

It shall be manufacturer's responsibility to be, or to become, knowledgeable of the requirements of these reference Standards and Codes. Any changes, alteration and necessary re-certification of the equipment for compliance with the applicable Standards and Codes shall be at the expense of the Manufacturer.

STANDARD	DESCRIPTION
IEC 60034	Rotating electrical machines (Part1 to Part15)
IEC 60038	IEC Standard Voltages
IEC 60050	International electromechanical vocabulary
IEC 60060	High voltage test techniques
IEC 60068-2-38	Test Z/AD: Composite temperature/humidity cyclic test
IEC 60072-1	Dimensions and output ratings frame numbers 56 to 400
IEC 60072-2	Dimensions and output ratings - frame 355 to 1000
IEC 60079	Electrical apparatus for explosive gas areas
IEC 60085	Recommendations for the classification of insulating materials in relation to their thermal stability in service
IEC 60182	Basic dimensions of winding wires
IEC 60529	Degrees of protection provided by enclosures (IP code)
IEC 60751	Industrial Platinum Resistance Thermometer Sensors
IEC 60851	Methods of test for winding wires
IEC 60894	Guide for test procedure for the measurement of loss tangent on coils and bars for machine windings
ISO 15	Rolling Bearings, Radial Bearings, Boundary Dimensions Rolling Bearings-Dynamic Load Ratings and Rating Life
ISO 9001:2000	Quality System Requirements
ISO 1132	Occupational Health and Safety Management Systems
ISO 14001	Environmental Management Systems

In addition to the above, the following codes shall be considered;

- NFPA-70 / National Electric Code
- API Recommend Practice 505
- Relevant British Standard Specification and Codes of Practice
- The Institute of Petroleum – Model Code of Sage Practice Electrical
- The Institute of Electrical Engineers, Regulations for Electrical Installation- Latest Edition.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 8 of 19
REV: 0
DATE: 07-JAN-2022

- Institute of Electrical & Electronic Engineers (IEEE)
- Electricity Act. (up –to-date) Govt. of Pakistan
- Oil & Gas (Safety in Drilling and Production) Regulation (up –to-date), Govt. of Pakistan.

In the event of conflict between Standards, the most stringent shall prevail.

All standards, regulations and codes of practices used shall be of latest current issues at the date of contract award.

The CONTRACTOR/VENDOR shall be responsible for the availability of the above mentioned specifications/publications, standards, and codes of practices and any other relevant documents and shall collect these documents on its own. The CONTRACTOR/VENDOR shall make sure that these documents are available all times and shall submit/present to COMPANY/CONSULTANT on request.

The design and installation shall also include the requirements of any applicable local laws, standards having jurisdiction over the site location following the principles and practices detailed in this document.

3. SERVICE CONDITIONS

3.1. Site Conditions

Following data presents the site and environmental conditions.

PARAMETERS	VALUE/UNIT
MAXIMUM AMBIENT TEMPERATURE	118 °F
MINIMUM AMBIENT TEMPERATURE	36 °F
WET BULB TEMPERATURE (DESIGN)	88 °F
MAXIMUM RELATIVE HUMIDITY	77%
MINIMUM RELATIVE HUMIDITY	20%
WIND VELOCITY	101 (Miles/Hour)
ELEVATION ABOVE MEAN SEA LEVEL (GPF)	250 ft.
SEISMIC ZONE	Zone 2A of Uniform Building Code- UBC-1997.

3.2. Power Supply Characteristics

The power supply system characteristics applicable to motors shall be as follows:

PARAMETERS	VALUE/UNIT
VOLTAGE	400 V ac \pm 10%, 3-PHASE 230 V ac 1-PHASE
FREQUENCY	50 Hz \pm 2%
NEUTRAL SYSTEM	SOLIDLY EARTHED
SPACE HEATER	230 V ac



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 9 of 19
REV: 0
DATE: 07-JAN-2022

4. MAIN DESIGN & CONSTRUCTION REQUIREMENTS

4.1. Design

Motors shall be three phase squirrel cage induction motors, explosion proof rating i.e. Ex d (for class-I, Zone-I) and Ex ec or type approved for zone-1 (for class-I, Zone-II) with non-sparking corrosion resistant fans (directly mounted on the motor shaft) of standard size, duty type S1 in accordance with IEC 60034 and shall not be adversely affected by long periods of inactivity in an environment that includes high humidity, storms, insects, plant life, fungus, rodents in conjunction with the environmental conditions as stipulated in "Section-3" of this specification. Motor shall be suitable for the application (driver) and shall suffice in all parameters to adapt the condition that normally present around or at the air cooler heat exchangers.

Motors for VFD operation shall be suitable for appropriate duty/service (S9) as per section 3.2 of IEC-60034.1. Similarly motor for delta/star starting shall have suitable nos. of leads for power cable connections. The torque-speed characteristic of the motor with starting method (as defined in single line diagram) shall be adequate for starting the driven load even under the most severe/worst conditions. Graphs showing the motor voltage-torque-current characteristics in respect of load torque characteristics from initial to rated speed shall be shared with COMPANY/CONSULTANT for review and approval.

The motor and all individual items forming part of the motor shall be suitable for outdoor use without protective shelter.

The required motor rating and speed will be as per driven equipment manufacturer. It shall be in accordance with IEC 60072 Parts 1 and 2 and be based on Class F insulation with temperature rise limited to Class B based on site maximum ambient temperature described in section-3 of this specification.

Motors shall be of standard size and shall have permanent spare capacities in accordance with API relevant API standard. However, in the absence of detail information, API-610 for pumps and API-673 for centrifugal fans shall be consulted.

Motors shall comply with IEC 60079 and shall be labeled or listed or certified by one of the world renowned third party.

The degree of protection shall be IP 42 for motors indoor in non-hazardous area; whereas IP 55 (motor enclosure), and "IP56" (motor terminal box - irrespective of mentioned in other documents) for motors outdoor & hazardous area, auxiliaries and bearing housings. It shall be in accordance with IEC 60529 classification of degree of protection by enclosures for electrical equipment.

Dimensions of foot-mounted motors, mounting flanges of motors and frame sizes shall be standard in accordance with International Standard IEC 60072.

Energy efficient motors are required for continuous duty application. The motor shall have power factor of not less than 0.90 at nominal load & at rated voltage.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 10 of 19
REV: 0
DATE: 07-JAN-2022

Motor shall be suitable for motor restart at 100% of residual voltage and at full opposition of phase.

The equipment covered by this specification shall be suitable for the specified operating conditions and shall be designed and constructed accordingly.

The power supply system characteristics applicable to motors shall be as follows:

PARAMETERS	VALUE/UNIT
VOLTAGE	400 V ac \pm 10%, 3-PHASE 230 V ac 1-PHASE
FREQUENCY	50 Hz \pm 2%
NEUTRAL SYSTEM	SOLIDLY EARTHED
SPACE HEATER	230 V ac

(*) All LV A.C induction motors with ratings above from 0.75 kW shall be supplied at rated 3-Phase supply i.e 400 Volts, 50Hz. Single phase 230V, 50Hz AC motors to be used only for the fractional and non-essential motors (for industrial use) of 0.75kW and below; however, 3-Phase (400V AC) motors shall be applied for classified / hazardous areas.

(**) All the motors shall be designed for direct on line operation (DOL) unless specified otherwise or any process conditions warranted the operation on VFD. In the latter case, motors shall be suitable for VFD starting and comply with relevant part of IEC-60034.

The torque – speed characteristics shall be adequate for starting the driven load under the most arduous conditions specified, e.g., open pump discharge valve and/or 80% rated voltage at motor terminals.

Motors shall be suitable for three starts in succession (coasting to rest between starts) with the motor initially at design ambient temperature or two consecutive starts (coasting to rest between starts) with the motor initially at a temperature not exceeding its rated load operating temperature. Otherwise, starting performance of motors, in general, shall be in accordance with IEC 34 Part 12.

Vibration in any direction as measured at the bearing housing and on the shaft shall not exceed the limits defined in IEC 34, Part 14.

Noise level shall comply with the limits defined in IEC 34 Part 9, in general, with a maximum of 85 dB.

The CONTRACTOR shall be completely responsible for the correct combined performance of the motor and its driven equipment package after installation.

If the CONTRACTOR takes any exceptions to the driven equipment specification or this specification, such exceptions shall be stated in his quotations, in a separate list for approval, any deviations / exceptions out of this list shall not be considered later on.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 11 of 19
REV: 0
DATE: 07-JAN-2022

4.2. Construction

4.2.1. Windings and Insulation

All motors shall have no hygroscopic insulation systems including leads and connections and shall be adequate for use in petrochemical plants. Insulation shall be Class F and the temperature rise B at design ambient condition described in section-3 of this specification. The temperature rise above the ambient conditions shall not be exceeding the limits/values given by IEC 34-1.

Coils shall be secured tightly in slots. Strand insulation shall adhere tightly to the strand. Strand and turn insulation integrity shall be maintained at all times. Additional turn insulation shall be used as required to maintain turn insulation integrity in the noses or other areas of coil deformation.

The insulation system shall be impervious to the service conditions specified above, and if oil mist lubrication is specified, all insulating materials used, including the lead insulation, shall be impervious to oil attack. Special provisions shall be made to seal the leads where they exit the coil.

Coil ends shall be braced to prevent insulation cracking and fatigue from motion during operation, starting and to withstand an external three phase short-circuit at full load and rated voltage.

All insulation systems shall be service proven and shall have had thermal evaluation in accordance with IEC 34, Part 18.

Stator lamination core plate shall be of at least C-5 quality per ASTM A 345. C-3 shall not be used.

All Motors rated 185 kW and above shall be provided with resistance thermometer detector (RTD's) embedded in the stator. Two (2) RTDs per phase shall be fitted. A separate terminal box on the motor enclosure shall be provided for connecting the RTDs to monitors.

4.2.2. Enclosures and Frames

Enclosure of motors shall generally be totally enclosed type and shall preferably be cast iron up to frame 315 or welded steel, corrosion resistant.

For fractional capacity motors, totally enclosed natural-ventilated (TENV) type enclosures are also acceptable.

Enclosures shall completely enclose the motors. Designs in which the stator laminations form a part of the enclosure or in which the stator laminations are otherwise exposed to external cooling air are not acceptable.

Casting shall be sound and free from shrink holes, cracks, scale, blisters or other similar injurious defects. Surface of castings shall be cleaned by sandblasting, shot blasting, pickling or any other standard method. All mold-parting fins and remains of gates and risers shall be chipped, filed, or ground flush.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 12 of 19
REV: 0
DATE: 07-JAN-2022

Totally enclosed motors in frames 254 and larger shall be equipped with an approved Stainless Steel drain at the lowest point of the frame.

Major parts such as frame components and bearing housings shall be designed and manufactured to ensure accurate alignment on re-assembly.

The frame shall be of cast iron or welded steel plate construction with removable end bells or end plates to permit removal of the rotor and facilitate replacement of stator coils. The frame shall be free from structural resonance within the applicable speed range.

The stress values used in the design of the frame shall not exceed the maximum allowable stress criteria specified in ASME Section VIII, for the material used.

The motor frame, including bearing supports, shall be designed to have sufficient strength and rigidity to limit changes of alignment caused by the worst combination of torque reaction, conduit / piping stress, magnetic imbalance and thermal distortion at the coupling flange and to permit the machine to be moved by using the lateral, axial and vertical jackscrews appropriately located to facilitate alignment.

Mounting plates shall be furnished, if required by the motor design, fitted with horizontal and vertical jackscrews of the same size.

Alignment dowels or rabbit fits shall be provided to facilitate disassembly and re-assembly of end bells or plates, bearing housing mounting plates and bearing housings. When jackscrews are used as a means of parting contacting faces, one of the faces shall be counter-bored or recessed to prevent a leaking joint or improper fit caused by marring.

The CONTRACTOR's Manufacturer shall determine jointly with the driven equipment manufacturer the common base frame and / or the alignment system of the motor on the base frame.

Tapped openings not connected to piping shall be plugged with solid corrosion resistant steel plugs furnished in accordance with ANSI B16.11. Threads shall be lubricated. Tape shall not be applied to threads of plugs inserted into oil passages.

Fan covers shall also be made of cast iron or cast steel and shall have a minimum rigidity equivalent to 3.18 mm steel plate. The air-intake opening shall be guarded by either a grill or by a metal screen made of Series 300 Stainless Steel with ¼" mesh. The screen holders shall be designed for easy removal and replacement of the screens while the motor is running.

Motor shall have adequate lifting and hoisting provisions.

The design of the enclosure and arrangement of the equipment, including terminal housings, auxiliaries, etc., shall provide adequate clearance areas and safe access for installation, operation, rapid and economical maintenance, cleaning and painting of the motor interior.

4.2.3. Rotating Elements

The rotating element shall be designed and constructed to withstand the starting duties specified.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 13 of 19
REV: 0
DATE: 07-JAN-2022

The shaft shall be one-piece, heat-treated forged steel, suitably ground. Suitable fillets shall be provided at all changes in shaft diameters and in keyways.

Welding of / or to shafts is not acceptable on two-pole motors, on shafting for balancing purposes, or on finished shafting. Any shafting and / or spiders subjected to welding must be post-weld stress relieved prior to finish machining.

Rotor laminations shall have no burrs in excess of 0.075 mm and shall be rotated when stacked to prevent uneven built up and to evenly distribute magnetic properties in grain orientation. The method of assembly shall prevent shaft surface scoring, assure positive positioning and minimize bowing.

Fabricated bar rotors shall be furnished with copper / copper alloy bars and end rings, replaceable without damage to air passages or laminations, maintained tight in the slot to limit vibration and fatigue. The rotor cage shall be maintained center locked (swedged, centered, pinned). End rings shall be without circumferential joints.

Rotors shall be dynamically precision balanced for the whole revolving mass, i.e., rotor, fan and half coupling sleeve supplied by the manufacturer of the driven equipment, in two or more planes. Final balance shall be performed after heat treating and / or baking. When a keyway is provided for a coupling hub, the rotor shall be balanced with the keyway fitted with a crowned half key to fill the useable length of the shaft keyway.

Shaft extension including keys and keyways shall be in accordance with IEC 72.

Balance weights added to the final assembly shall be Series 300 Stainless Steel. The use of solder or similar deposits for balancing purposes is not acceptable. If parent material is to be removed to achieve dynamic or static balance, it is to be drilled out in a manner that will maintain the structural integrity of the rotor and will not cause harmful or distortive hot spots in operation. Chiseling, sawing or torch burning is not permitted.

Motors shall be fan-ventilated type to meet the requirements of IEC 34 Part 6 to IC 0151.

Fans shall be of non-sparking corrosion resistant material and shall force the cooling air from non-driving end toward the driving end. Air inlet and discharge openings shall be arranged to prevent re-circulation of cooling air through the motor.

Fans shall be permanently indexed angularly and axially and shall be mounted by either Split hub or Shrink-fit on shaft methods. Split fans secured only with set-screws to the shaft are not acceptable.

The direction of rotation for which motor is arranged shall be clearly indicated by means of an arrow on the non-driving end and shall be Series 300 Stainless Steel or nickel-copper alloy, whichever suitable, securely fastened by pins of suitable material and shall be located of easy visibility. A paint arrow only is not sufficient.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 14 of 19
REV: 0
DATE: 07-JAN-2022

4.2.4. Bearings and Lubrication

Sealed pre-lubricated ball and roller bearings are preferred for small motors (Frame size 180 or less) to provide a trouble free service of 3 to 5 years without the necessity of re-lubrication.

Ball and roller bearings shall be of reputable manufacturer and of a type interchangeable with other makes, preferably in cartridge type housing.

Grease or lubricated bearings shall be used for motors bearing housings for grease lubricated bearings shall be provided with exterior fill and release plugs in taped holes. Grease fittings are not acceptable release plugs must be large enough to relieve bearings without grease getting in to motor. Sealed pre lubricated ball bearings are acceptable only for small motors (frame size 180 or less)

It is the responsibility of the motor manufacturer to provide correct bearing for the application, in accordance with relevant Codes & Standards. However, for special drives with high radial forces the application of roller bearings or a combination of ball and roller bearings at the drive-end side may be necessary. Bearings shall be protected to eliminate contamination, loss of lubricant and to prevent intrusion of fine dust and sand particles.

Vertical motors driving direct coupled pumps shall have the thrust bearing at the non- drive end (NDE). The rating plates shall be fixed to a non-removable part of the frame. Information provided on the rating plates shall be in accordance with IEC 60034-1.

4.3. Accessories

4.3.1. Terminal Boxes and Terminals

Motors shall be equipped with a main terminal box for motor supply cables and auxiliary terminal boxes for anti-condensation heater, winding temperature detectors, where applicable.

Main terminal boxes on the horizontal motors shall be on the right side, whereas, auxiliary terminal boxes shall be on the left side when facing the non-drive-end (shaft extension).

All terminal boxes shall be made of cast iron or steel, unless otherwise specified, with a minimum rigidity equivalent to 3.18 mm steel plate. Minimum dimensions and useable volumes shall not be less than those given in ANSI C50.41.22. When required, larger boxes shall be provided for special cable terminations and / or additional devices. Terminal boxes and auxiliary equipment enclosures shall be suitable for the conductor entry, as required, and shall be furnished with compression type cable glands (ISO metric), water tight and fully gasketed.

The terminal boxes and gland plates shall be so arranged as to allow for the disconnection and removal of the incoming cable(s) without disturbing the motor windings terminations or the seal between the motor frame and terminal box.

Each terminal box other than explosion proof shall have a bolted, gasketed cover fully accessible from the front and arranged for convenient access. Gasketing material shall be non-sticking, non-hygroscopic, re-usable, shall not require grease or other applicable compound and shall be impervious to oil attack.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 15 of 19
REV: 0
DATE: 07-JAN-2022

Terminals, leads and associated fittings shall be able to withstand conditions of a through fault when connected to the plant electrical system.

Motor terminals shall be clearly and permanently marked with reference letters in accordance with applicable standards.

The choice of direction or its modification shall be possible on the work site by means of standard tools.

4.3.2. Space Heater

Motors anti-condensation heater shall be as per manufacturer recommendation in view of ambient condition (refer sec.3) and motor winding life. However; motors equal and greater than **22 kW** and above shall be provided with anti-condensation heaters irrespective of manufacturer recommendation. The space heaters shall be energized while the motors are stopped and shall be arranged to provide uniform heating of the stator windings. The heaters shall maintain the temperature of the motor windings approximately 5°C above ambient temperature. The surface temperature of the heater elements shall be in accordance with the requirements of area classification.

The space heater leads shall be brought out into a separate terminal box from the motor main terminal box.

The space heaters shall be rated 230 V, single phase, 50 Hz.

4.3.3. Grounding Terminals

Each motor shall be provided with two external grounding terminals on the motor frame and an internal grounding terminal inside each terminal box. The grounding terminal and wiring shall be clearly and permanently identified.

The screw, stud or bolt intended for the termination of a grounding conductor shall be of a suitable size for the attachment and shall have equivalent fault current ampacity of a copper grounding conductor required per motor full load current. External tooth lock washers, serrated screw heads, or the equivalent shall not be furnished for a screw, bolt, or stud intended as a grounding conductor termination.

The terminals shall be solder less type and shall be on a part of the machine not normally disassembled during operation or servicing.

4.3.4. Nameplates

The nameplate shall be Series 300 Stainless Steel securely fastened by pins of similar material and shall be located for easy visibility.

The rated conditions and other data, as below, shall be clearly stamped on the nameplates:

- Manufacturer's name.
 - Serial number.
 - Motor Item Number.
 - Model Number.
-



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 16 of 19
REV: 0
DATE: 07-JAN-2022

- Duty Type.
- Design Class
- Enclosure type.
- Frame Size
- Horsepower and kW rating.
- Voltages.
- Phases.
- Frequency.
- Efficiency.
- Power Factor.
- Full Load Amperes (FLA)
- Locked-Rotor Amperes (LRA)
- Full Load Speed (RPM)
- Service factor.
- Temperature Class.
- Direction of Rotation
- Bearing Nos. and Manufacturer.
- Oil flow rate (gpm, for flood lubricated bearings)
- Hazardous Area Classification / IP Classification for weather protected motors.

Separate connection diagrams or data nameplates shall be located near the appropriate connection box for the following:

- Space heaters (Operating voltage and wattage).
- Connections of proper rotation.
- Instruction for lubrication, with bearing numbers.

4.3.5. Finish

The exterior shall be thoroughly cleaned, scraped and wire brushed to remove all rust, grease and dirt. Immediately after preparation the exterior shall be primed and painted as per painting specification.

4.4. Test and Inspection

Manufacturer shall submit the following data available for examination by the COMPANY/CONSULTANT during inspection at the Manufacturer's works:

- All necessary certification of materials such as mill test reports on shafting, forging and major castings.
- Test data to verify that the requirements of the specification have been met.
- Results of all quality control tests and inspections.

The motors shall be factory tested as per the requirements of Codes and Standards mentioned above.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 17 of 19
REV: 0
DATE: 07-JAN-2022

Each motor shall be given a routine test to demonstrate that it is free from mechanical and electrical defects. This test shall be conducted in accordance with the applicable portions of Codes and Standards mentioned above.

This test shall include, but not limited to the following:

- Measurement of no-load current (each phase).
- Measurement of nominal no-load speed.
- A determination of locked-rotor current.
- Stator and Rotor copper and core losses.
- A high-potential test.
- An insulation resistance test by meg-ohmmeter.
- Measurement of winding resistance.
- Measurement of vibration.
- Measurement of noise.
- Air gap measurements.

The following basic requirements shall be met for all running tests:

- Tests shall be made on the fully assembled motor including contract components, accessories, etc.
- If applicable, all oil pressures, viscosities and temperatures shall be at the same operating values recommended in the Manufacturer's operating instructions for the specific unit under test. Oil flow rates for bearing housings shall be determined.
- All warning, protective and control devices shall be checked and adjustments made as required.

During the running test, the mechanical operation of all equipment being tested and test instrumentation shall be satisfactory. Calibration certification shall be presented for client witness.

Facilities to ensure against entrance of oil into the motor shall be in operation throughout the test.

The Manufacturer shall maintain a complete, detailed log and plot of all final tests and shall submit the required number of copies to the COMPANY/CONSULTANT, including data for rotor balancing and vibration measurements taken over the operating speed range and the non synchronous sweep. A description of the test methods and instrumentation and certified copies of the instrument calibrations shall also be provided along with the above mentioned for the COMPANY/CONSULTANT's review.

5. GUARANTEE

The CONTRACTOR shall guarantee that the equipment furnished is free from fault in design, workmanship, is of adequate size and capacity, and of proper material to satisfactorily fulfil the operating conditions specified. Should any defect in design, material, workmanship or operating characteristics develop during the first year of operation, the CONTRACTOR shall make all



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 18 of 19
REV: 0
DATE: 07-JAN-2022

necessary alterations, repairs and replacements of defective equipment / components, at his own cost including transportation, installation and testing.

6. SHIPPING

Motors shall be suitably prepared for the type and mode of shipment such that these arrive at their destination in undamaged condition.

7. DOCUMENTS

For each motor, the CONTRACTOR/Manufacturer shall complete and submit motor data sheets at the time of bidding. Required number of copies of the vendor's design drawings and As-built information shall be submitted, which shall include, but not limited to the following:

- Certified copies of shop test data.
- Motor torque versus speed at rated voltage and at 80% of rated voltage.
- Motor current versus speed at rated voltage, at 90% of rated voltage and at the anticipated starting voltage.
- Rotor Balance report.
- Estimated times for acceleration at rated voltage, at 90% of rated voltage and the anticipated starting voltage.
- Standard and Maximum available efficiencies at $\frac{1}{4}$, $\frac{1}{2}$, $\frac{3}{4}$, and full load and the service factor.
- Power factors at the same loads as required above for both standard efficiencies and maximum available efficiencies.
- Lubrication oil required, including the quantity of lubricating oil required at supply pressure and the heat load to be removed by the oil. Approximate data shall be defined clearly as such.
- Net weights and maximum erection weights with identification of the item. These data shall be stated individually where separate shipments, packages or assemblies are involved.
- List of all vendor drawings.
- Dimensional outline drawings showing the location of inlet and discharge connections and the direction of rotation when the motor is viewed from the non drive end.
- Schematic diagrams of the lube-oil system.
- Bills of material for all auxiliary systems within the scope of supply, including control systems and dimensional outline drawings for accessories and instruments. Bills of material shall include and identify all components by make, type, size, capacity rating, materials and other data as applicable.
- Cross-sectional drawings and literature to fully describe the details of the offering(s) showing shaft sealing details, shaft dimensions, bearing details, internal construction, rotor construction and the method of attaching the rotor bar to the shorting ring.
- Erection / assembly drawings.
- Recommended spare parts list (Startup and 2-year maintenance).
- An itemized list of any special tools included in the offering(s).
- Installation, operation and maintenance manuals.



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY COMPRESSION PROJECT
SPECIFICATION FOR LV A.C INDUCTION MOTOR

DOC NO: 0258-ELA-6502
PAGE: 19 of 19
REV: 0
DATE: 07-JAN-2022

- Technical Specification
- Installation Drawings
- Test Certificates
- WK^2 (moment of inertia) of the motor rotor
- WK^2 of the driven equipment, referenced to the same rpm as the motor rotor

The drawings furnished shall contain sufficient information; the size, type, location and identification of all auxiliary or other equipment, rigging provisions and connections, including power, control, and instrument wiring, supply and drain details for lubricating oil and inlet and discharge details for cooling air, as well as frame vents and drains including manufacturer plugged connections, so that when they are combined with the manuals, as above, the ordered equipment shall be properly installed, operated and maintained.