



CABLE ROUTE MARKER POSTS & SIGNS

ITEM NO.	DESCRIPTION
1	CABLE ROUTE MARKER SIGN PLATE (S.S.) 95x95x1.5t
2	ANCHOR BAR 100L
3	ROUTE MARKER POST (CONCRETE)

NOTES:-

1. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
2. SIGN PLATES SHALL BE 95MMx95MMx1.5MM THICK.
ARROW MARK AND LETTERING SHALL BE ENGRAVED ON
PLATE AND SHALL BE COLORED IN RED AND SHALL BE
ERECTED AT A 20 METER INTERVAL ALONG THE STRAIGHT
TRENCH AND AT EACH BEND FOR INDICATION OF
PRESENCE OF UNDERGROUND CABLES.
3. ARROW HEADS ON MARKER LABELS TO BE EQUILATERAL
WITH 20MM SIDES.
4. MARKER TO BE SUNK TO GROUND LEVEL ON ROAD
WAY CROSSING .
5. LETTERING SHALL BE W.R.T CABLE TYPE LAID, CLEARLY
INDICATING THE VOLTAGE GRADE ALONG WITH SIGN
OF "DANGER".
i-e :
 - 0.4kV
 - L.V CABLES

RE-ISSUED FOR TENDER

1	25-02-2022	RE-ISSUED FOR TENDER	MAA	JAB	AIB	PM	MAS
0	07-01-2022	ISSUED FOR TENDER	MAA	JAB	AIB	PM	MAS
A	29-10-2021	ISSUED FOR REVIEW	MAA	JAB	AIB	PM	MAS
REV.	DATE	DESCRIPTION OF REVISION	DRAWN	DESIGN	CHKD.	QC	APPR.
<div><div><div>ENAR</div></div><div>7-B, Sector 7-A Korangi Industrial Area, Karachi Pakistan TEL: (9221) 5062791 E-mail: info@enar.com.pk URL:www.enar.com.pk</div></div>			Job No. 14-0258				
			Dwg. No. 0258-ELF-6801 Sheet-15				
OIL & GAS DEVELOPMENT COMPANY LTD.							
TITLE: KPD - TAY COMPRESSION PROJECT TYPICAL INSTALLATION DETAILS CABLE ROUTE MARKER POSTS & SIGNS			COMPUTER CODE		0258-ELF-6801		
			SHEET SIZE		A3		
			SCALE		1:1100		
			REPLACES DWG. NO.				
			THIS DOCUMENT IS THE PROPERTY OF ENAR & THE CONTENTS MUST BE TREATED AS CONFIDENTIAL				