

Dated: 08-04-2024


CLARIFICATION/AMMENDMENT # 1

TENDER ENQUIRY # TE/MOF/ELECT/10018888/2024

“Supply of Earthing Material and construction of earth pits complete in all respects at Mela-6 Facility”

Following may please be noted to clarify the schedule of requirement against aforementioned tender:

1. Minimum Diameter of copper rod (10ft) is 3/4 “.
2. BOQ mentioned in schedule of requirement is mandatory to be supplied as minimum scope of supply. However Bidder shall supply additional material required to achieve less than one OHM resistance. Bidder may visit site for careful estimation.


AHMED ZIA
Chief Engr (ELECT) P&P
Ext 4160