

**CLARIFICATION NO. 07**

**TENDER NO. PROC-FC/CB/PROD/NASHPA-2034/2017**

**SCADA SYSTEM FOR NASHPA WELLS**

Reference to clarification No. 06, following line at S. No 65 may please be amended and read as follows:-

Clarifying issues	OGDCL Response
Non SIL RTU and MTU is required, please confirm.	All PLC / MTU/ RTU shall be SIL-2 compliant.