

CLARIFICATION#2 AGAINST TENDER # PROC-SERVICES/CB/P&P-4701/2020 – FOR CONDITION MONITORING/ VIBRATIONAL ANALYSIS INSPECTION SERVICES

One of the potential bidder has asked following clarifications. OGDCL response is as under:-

Sr#	Questions for Clarification	OGDCL Reply
1	Do you required data acquisition (@Sr. 1 Financial Bid Format at Page 15) and detailed vibration analysis (@Sr. 2 Financial Bid Format at Page 15) in same visit as number of visits of both services are same. Or service @ Sr. 2 will be required on as and when required basis.	Both the services can be obtained in parallel as at Sr.No.01: Vibration Analysis will be obtained while at Sr.No.02 Detail Analysis will be performed for machines.
2	Number of equipment list per sites	Equipment lists varies from site to site and different categories are mentioned in TOR's.
3	visit frequency	It will on quarterly basis as well as on call basis for emergency or planned visits for any specific requirement from sites.
4	Number of samples per sites for oil analysis	Oil Samples are not fixed field wise and they will be offered on requirement basis from sites.
5	Engaged Engineers in last contract (# of specialists/technicians)	Confidential, it is the responsibility of contractor to plan jobs in parallel at different locations/sites.
6	Work scope involves in each technology:	
a.	Number of Tests involve in Transformer testing. Can you specify which specific test/s are required.	Will include condition monitoring based tests on requirement basis may be like winding tests, frequency tests, oil tests
b.	Only MCSA is desire not Electrical Signature Analysis (ESA)	Only MCSA
c.	Stress analysis/RCFA	On requirement basis to confirm any other contributing factors in vibration of machines like piping stress etc