

**CLARIFICATION#3 AGAINST TENDER # PROC-SERVICES/CB/P&P-4875/2020- ATA QADIRPUR PLANT**

Following Clarification has been made in the subject tender.

<b>S. No.</b>	<b>Query</b>	<b>OGDCL Reply</b>
1	Please confirm purging and flushing will be done by client. Further hot tapping of live lines will be done by client.	It is hereby confirmed that Purging/flushing will be done by client as per previous practice during last ATA. Hot tapping of live lines is not required as this is a plant shutdown activity.