Clarification

Design, Manufacturing and Supply of Auxiliary Boiler along with Boiler Feed Water Pumps for Dakhni Plant.

PROC/LF/PT/P&P/DKN-17207-A/18

Question. Temperature and %age of condensate return at boiler?

Answer: Feed Water Temperature 85 C %age Return condensate 85%