

Ref: Clarification#1

Dated: 16.11.2018

SUBJECT: CLARIFICATION PRIOR TO BID PROC-LD/PT/P&P-DKN/17453/18

Query raised by a prospective bidder:

“ You have asked **Zone- 0 Light** which is normally used in Coal mines and very rare for Oil & Gas plant application. As per our experience, Zone-1 Lights are used for Oil & Gas fields.

Kindly check at your end whether you really need Zone-0 Light or Zone-1 Light ? so that we could work accordingly with our Principals. We can also arrange Zone-0 lights if OGDCL really needed in this particular tender.”

Reply:

Reply to above query:

Explosion proof class for subject tendered lights may please be considered as zone-1 class 1 however Zone-o class 1 will also be acceptable..