

Clarification # 2

PROC-LD/PE&FD/17629 ELECTRICAL LIGHTING ITEMS

Query # 1: Refer to Group A, Kindly confirm us the LED Light is acceptable for you with same required specifications.

OGDCL Reply: LED light is not acceptable.

Query # 2: Refer to Group C: Sr # 3, Single core cable not come with SWA, Therefore; Please confirm that required cable is SWA OR AWA (Aluminium Wire Armoured).

OGDCL Reply: SWA was typo error and considered as deleted.

Query # 3: Group -B, Electrical Poles. OGDC has asked for CS material for pole, whereas our pipe manufacturer has supplied electrical poles of GI material to CDA, NHA, DHA, Bahria Town & in KPK. Kindly advise if this shall be acceptable to OGDCL, as it will be cost effective....

OGDCL Reply: In addition to CS material, GI material is also acceptable for healthy competition.

Query # 4: Refer to Group -C for armoured power cables. Item #3 is single core armoured electric power cable 10mm. Principals of renowned cable manufacturer (Pakistan Cables, FAST Cables or AG Cables etc.) states that since size is small non- armouring is possible. Besides we note that there may be a typo error as unit of measurement is mentioned in Numbers instead of Meters against same item.

OGDCL Reply: SWA was typo error and considered as deleted. Unit of measurement mentioned as numbers is also typo error and considered as in Meters.