



DAKHNI GAS PLANT INSTRUMENT UPGRADATION
TENDER ENQUIRY # (PROC-FC/CB/P&P/DKN-2056/2017)



PRE-BID CLARIFICATION # 02

| S.No. | DOCUMENT REFERENCE | BIDDER'S QUERY | RESPONSE FROM OGDCL/ENAR |
|----------------|---|--|-------------------------------------|
| GENERAL | | | |
| 1 | TENDER ENQUIRY # (PROC-FC/CB/P&P/DKN-2056/2017) | "In this tender most of the items are for pressure positioned (I/P positioned) which have been replaced by E/P positioner. So, will OGDCL accept the replacement or will they need only I/P positioned?" | E/P Positioner are also acceptable. |