



DAKHNI GAS PLANT INSTRUMENT UPGRADATION
TENDER ENQUIRY # (PROC-FC/CB/P&P/DKN-2056/2017)



PRE-BID CLARIFICATION # 03

S.No.	DOCUMENT REFERENCE	BIDDER'S QUERY	RESPONSE FROM OGDCL/ENAR
GENERAL			
1	TENDER ENQUIRY # (PROC-FC/CB/P&P/DKN-2056/2017)	<p>For Item# 6 to 69 (As per OGDCL Schedule of Requirement; Annexure "A"):</p> <p>We note that OGDCL requires I/P Positioner (input signal shall be 4 to 20 mA, 24V dc with HART as per OGDCL technical specs). Therefore, we request you to kindly advise existing Fisher Actuator details i.e. Type, Size & Travel and also furnish us S/Nos. of existing Fisher Actuators installed at your plant so that we shall quote you exact mounting kits for required I/P positioner.</p>	<p>Details of existing actuators installed are not available. Furthermore we do not foresee requirement of such details are necessary.</p>
2		<p>Kindly note that 2" Pipe mounting kits are not applicable for I/P Positioner as mentioned in OGDCL subject tender specs.</p>	<p>Bidder shall supply manufacturer standard mounting/installation kits.</p>