



**DAKHNI GAS PLANT INSTRUMENT UPGRADATION
TENDER ENQUIRY # (PROC-FC/CB/P&P/DKN-2057/2017)**



PRE-BID CLARIFICATION # 03

S.No.	DOCUMENT REFERENCE	BIDDER'S QUERY	RESPONSE FROM OGDCL/ENAR
GENERAL			
1	PROC-FC/CB/P&P/DKN-2057/2017	<p>For Item# 41 & 42 for Control Valves (LCVs) {AS PER OGDCL SCHEDULE OF REQUIREMENT;ANNEXURE"A"} We note that data sheets & specs of above referred items are not included as per attached subject web tender. We request you to kindly send us for the same.</p>	<p>Please note that Item# 41 & 42 are shutdown valves not control valves. Refer Shutdown Valve technical specification Annexure-A as attached in tender document.</p>
2		<p>For Item# 43,46 to 50 for LY (AS PER OGDCL SCHEDULE OF REQUIREMENT;ANNEXURE"A") We note that specs of above referred items are not included as per attached subject web tender. We request you to kindly send us for the same.</p>	<p>Please note that Item# 43, 46 to 50 are solenoid valves. Refer technical specification Annexure-A as attached in tender document.</p>
3		<p>For Item# 44 & 45 for XY (AS PER OGDCL SCHEDULE OF REQUIREMENT;ANNEXURE"A") We note that specs of above referred items are not included as per attached subject web tender. We request you to kindly send us for the same.</p>	<p>Please note that Item# 44 & 45 are solenoid valves. Refer technical specification Annexure-A as attached in tender document.</p>