



Date: April 03, 2018

PRE-BID CLARIFICATION # 03

Subject: **TENDER NO. PROC-FC/CB/PROJ/KPD-3136/2017 FOR SUPPLY OF MECHANICAL, ELECTRICAL, INSTRUMENTATION AND TELEMETRY WORKSHOP EQUIPMENT**

Sr. No.	Bidder's Query	Response from OGDCL
1.	<p>In tender documents, for item-b of GROUP – E (ELECTRICAL INSPECTION TOOLS); Please note that the required LENGTH UP TO 2KM mention at BOQ/BID PRICE SCHEDULE while in SECTION – IV , Sr. No. 3.5(Group-E: Electrical Inspection Tools) at S. No# 2, the required length up to 5km. So you are requested to please clarify and confirm that which length range is required?</p> <p>More over Please provide transmitter ranges, receiver ranges & other details as required for better selection of equipment</p>	<p>Required Cable length for cable fault locator is 02 KM.</p> <p>Transmitter and receiver of such ranges should be used which meet cable length and depth already provided in the tender document.</p>