



# NASHPA COMPRESSION FACILITY PROJECT



Tender Enquiry No.: PROC/FC/CB/PROJ/NASHPA-3268/2018

## PRE-BID CLARIFICATION # 07

One of the bidder has asked following queries, OGDCL/ENAR responses are as follows:

Sr. No.	Clarification By Bidder	OGDCL / ENAR Response
1	<p><b>Section (with Page No):</b> Section-III</p> <p><b>Subject:</b> NGP-000-SCW-15.01-2003-23-01- Road &amp; Pavement Layout</p> <p><b>Question:</b> Clarification for Civil work Kindly provide the detail drawing for concrete brick pavement.</p>	Refer Drawing No. NGP-000-SCW-15.01-2003-23 (Sheet 5 of 7).
2	<p><b>Section (with Page No):</b> 0193-PB-2101-0 (P&amp;ID For Front End Compressors) 0193-DS-6000-0 (Vortex Flowmeter)</p> <p><b>Subject:</b> FT-2010 type selection</p> <p><b>Question:</b> The type of data table description is vortex street flowmeter, the symbol of P&amp;ID is turbine flowmeter, please confirm which type of instrument is selected.</p>	Vortex Type Flow Meter is considered for Tag FT-2010.