



NASHPA COMPRESSION FACILITY PROJECT



PRE-BID CLARIFICATION # 01

One of the bidder has asked following queries, OGDCL/ENAR responses are as follows:

Sr. No.	Clarification By Bidder	OGDCL / ENAR Response																																																
1	<p>Description Sec-III Scope of Work 12.4.4.3 Reliability Guarantee Test (RGT) The continuing availability of the Nashpa Compression Facility to deliver required gas/ liquid flow rates and pressures up to and including the design maximum day flow at the contractual delivery pressure and temperature shall be demonstrated by means of a Reliability Guarantee Test. This Test shall start on completion of the Performance Guarantee Test to the satisfaction of OGDCL/Consultant and shall continue for a minimum of 90 days.</p> <p>Sec- IV CONDITIONS OF CONTRACT 14.0 PROJECT COMPLETION PERIOD The Contractor is required to complete the design engineering, procurement, construction, installation / erection, pre-commissioning, commissioning and start-up (including performance testing and Reliability Guarantee Test) of Nashpa Compression Facility Project within Eleven (11) months from date of establishment of supply letter of credit for foreign component. The Work schedule is given in Appendix – D.</p> <p>However, the Works schedule as Appendix-D doesn't mention the Reliability Guarantee Test. And the duration of Commission/start-up/performance test is 29 days. Meanwhile, the commencement date is 2018.4.6 and the completion date is 2019.3.5, which means that total time for completion is 11 months.</p> <table border="1" data-bbox="170 878 1104 1040"> <thead> <tr> <th colspan="4">OGDCL-NASHPA COMPRESS</th> </tr> <tr> <th>ID</th> <th>Task Name</th> <th>Start</th> <th>Finish</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>NASHPA COMPRESSION PROJECT EPCC SCHEDULE</td> <td>Mon 6/4/18</td> <td>Fri 5/3/19</td> </tr> <tr> <td>2</td> <td>Preparation of P&IDs and Datasheets</td> <td>Mon 6/4/18</td> <td>Fri 7/6/18</td> </tr> <tr> <td>3</td> <td>Detailed Engineering design for Mechanical/Electrical/Instrumentation /Civil</td> <td>Mon 7/2/18</td> <td>Fri 10/12/18</td> </tr> <tr> <td>4</td> <td>Issuance of IFC Drawings/Documents</td> <td>Mon 10/15/18</td> <td>Fri 10/19/18</td> </tr> <tr> <td>5</td> <td>Delivery of Compressor Package</td> <td>Mon 9/10/18</td> <td>Fri 12/28/18</td> </tr> <tr> <td>6</td> <td>Delivery of other long lead items</td> <td>Mon 9/10/18</td> <td>Fri 12/28/18</td> </tr> <tr> <td>7</td> <td>EPCC Contractor mobilization on Site</td> <td>Mon 10/29/18</td> <td>Fri 11/2/18</td> </tr> <tr> <td>8</td> <td>Civil Works</td> <td>Mon 11/5/18</td> <td>Fri 1/25/19</td> </tr> <tr> <td>9</td> <td>Mechanical/Electrical/Instrumentation Works</td> <td>Mon 11/5/18</td> <td>Fri 3/22/19</td> </tr> <tr> <td>10</td> <td>Commission / Startup / Performance test</td> <td>Mon 3/25/19</td> <td>Fri 5/3/19</td> </tr> </tbody> </table> <p>Clarification Request: It is conflictive between the provision of Sub-Clause 14 of Sec-IV and Works Schedule of Appendix-D. We understand the 11 months shall not include the time of RGT. Please confirm whether the Time for Completion of the Project (11 months) includes time of Reliability Guarantee Test.</p>	OGDCL-NASHPA COMPRESS				ID	Task Name	Start	Finish	1	NASHPA COMPRESSION PROJECT EPCC SCHEDULE	Mon 6/4/18	Fri 5/3/19	2	Preparation of P&IDs and Datasheets	Mon 6/4/18	Fri 7/6/18	3	Detailed Engineering design for Mechanical/Electrical/Instrumentation /Civil	Mon 7/2/18	Fri 10/12/18	4	Issuance of IFC Drawings/Documents	Mon 10/15/18	Fri 10/19/18	5	Delivery of Compressor Package	Mon 9/10/18	Fri 12/28/18	6	Delivery of other long lead items	Mon 9/10/18	Fri 12/28/18	7	EPCC Contractor mobilization on Site	Mon 10/29/18	Fri 11/2/18	8	Civil Works	Mon 11/5/18	Fri 1/25/19	9	Mechanical/Electrical/Instrumentation Works	Mon 11/5/18	Fri 3/22/19	10	Commission / Startup / Performance test	Mon 3/25/19	Fri 5/3/19	<p>Bidder's understanding is correct i.e. The Time for Completion of the Project (11 months) does not include Ninety (90) days time of Reliability Guarantee Test. In the light of this clarification, following documents and their respective clauses shall now be read as follows:</p> <p>1- <u>Section-II (Instructions to Bidders), Clause 1.4 (Page 5 of 29)</u> "The timely completion of the Project by the Contractor shall be the essence of the Contract, as OGDCL has to meet its obligations for completion of the Project and continuation supply of Gas. Accordingly, the Contractor (Successful Bidder) is required to complete the design engineering, procurement, construction, installation / erection, pre-commissioning, commissioning, startup and performance testing of Nashpa Compression Facility Project within Eleven (11) months from date of establishment of supply letter of credit for foreign component. The Work schedule is given in Appendix – D".</p> <p>2- <u>Section-IV (Conditions of Contract), Clause 14.0 (Page 22 of 73)</u> "The timely completion of the Project by the Contractor shall be the essence of the Contract, as OGDCL has to meet its obligations for completion of the Project and continuation supply of Gas. Accordingly, the Contractor (Successful Bidder) is required to complete the design engineering, procurement, construction, installation / erection, pre-commissioning, commissioning, startup and performance testing of Nashpa Compression Facility Project within Eleven (11) months from date of establishment of supply letter of credit for foreign component. The Work schedule is given in Appendix – D".</p> <p>3- <u>Section-IV (Conditions of Contract), Clause 29.0 (a) (Page 39 of 73)</u> "If the Contractor fails to complete the engineering, procurement (supply), construction, pre-commissioning, commissioning, start-up and performance testing of Nashpa Compression Facility Project within the time period of Eleven (11) months, then Company shall, without prejudice to other remedies under the contract, deduct from the contract price / Bank Guarantee as liquidated damages, a sum not more than 0.5% of the contract price per week or part thereof for first four weeks, 1.00% per week for next four weeks and 1.5% per week exceeding four weeks up to maximum extent of 10 % of the contract value."</p>
OGDCL-NASHPA COMPRESS																																																		
ID	Task Name	Start	Finish																																															
1	NASHPA COMPRESSION PROJECT EPCC SCHEDULE	Mon 6/4/18	Fri 5/3/19																																															
2	Preparation of P&IDs and Datasheets	Mon 6/4/18	Fri 7/6/18																																															
3	Detailed Engineering design for Mechanical/Electrical/Instrumentation /Civil	Mon 7/2/18	Fri 10/12/18																																															
4	Issuance of IFC Drawings/Documents	Mon 10/15/18	Fri 10/19/18																																															
5	Delivery of Compressor Package	Mon 9/10/18	Fri 12/28/18																																															
6	Delivery of other long lead items	Mon 9/10/18	Fri 12/28/18																																															
7	EPCC Contractor mobilization on Site	Mon 10/29/18	Fri 11/2/18																																															
8	Civil Works	Mon 11/5/18	Fri 1/25/19																																															
9	Mechanical/Electrical/Instrumentation Works	Mon 11/5/18	Fri 3/22/19																																															
10	Commission / Startup / Performance test	Mon 3/25/19	Fri 5/3/19																																															
2	<p>Description: It is noticed that there are Existing Raw Water Pond and Water Pump mentioned on Volume II –E (Civil) Drawing no. NGP-000-GEN-15.01-0002-00. This area will be filled as the foundation of compressors in according to the Plot plan provided by you.</p> <p>Clarification Request: Please provide the size of the raw water pond and confirm whether a similar raw water pond will be designed and constructed or not.</p>	<p>The Project area would be cleared by OGDCL for any other installation, as already mentioned in para No. 5 of clause 12.3.12 "Civil and Structural Work" of Section-III, Scope of work. Furthermore, Raw water pond will not be designed/constructed for the project.</p>																																																