

Ref: Clarification#1

Dated: 26.09.2018

SUBJECT: CLARIFICATION PRIOR TO BID (TE # PROC-FE/CB/P&P-4057/2018)

Query raised by a prospective bidder:

- i. Overall diameter of 4x16 SQ.MM armored cable in order to select the appropriate cable gland.
- ii. Overall diameter of 3x2.5 SQ.MM armored cable in order to select the appropriate cable gland.

Reply to above query:

- i. Overall diameter of 4x16 SQ.MM armored cable is 27.1 mm
 - ii. Overall diameter of 3x2.5 SQ.MM armored cable is 14.6 mm
- 1/11 1/2