

Ref: Clarification#2

SUBJECT: **CLARIFICATION PRIOR TO BID (TE # PROC-FE/CB/P&P-4057/2018)**

Query raised by a prospective bidder:

"The Attachment for specs. requires that junction box shall be in round shape.

However size is given of a square J.B i.e 300 x 300 x 150 mm

We would like to know if we can quote for Square shape of the same size."

Reply to above query:

Required JB is of square shaped having given dimensions with threaded circular/round shaped removable cover/lid.