

Ref: Clarification#1

Dated: 29.10.2018

SUBJECT: CLARIFICATION PRIOR TO BID (TE # PROC -FE/CB/P&P/4080/2018)

Query raised by a prospective bidder:

“Reference to the subject tender, we have one following doubt.

1. You just need ONE battery set consisting of 43 pieces of cell type MC110P (or equivalent)

OR

2. Do you need more battery sets? In that case, how many sets?”

Reply to above query:

We need battery cells for two battery banks comprising of 20 battery cells in each and remaining 03 Nos. as additional.