## PROCUREMENT (SUPPLY), CONSTRUCTION, INSTALLATION/ERECTION, PRE-COMMISSIONING, & COMMISSIONING ASSISTANCE FOR NEW CENTRIFUGAL COMPRESSORS AND MODIFICATION WORKS OF EXISTING TURBO COMPRESSOR TRAINS FOR QADIRPUR COMPRESSION PROJECT

## TENDER ENQUIRY NO. PROC-FC/CB/PROJ/QP-4369/2019 POST-BID CLARIFICATION No. OGDCL-QP-4369-022



Sr. No.	Bidder Query	OGDCL/ENAR Response (08-Nov-2019)
1	Please elaborate -13.5 ft NPSHa and how it is applied/calculated for rated conditions.	It is note that the suction connection of pumps P-2501A/B are in underground Pit. Whereas, the pumps shall be installed on ground due to area restriction in pit. For calculation 10 ft elevation difference is used. Moreover, the NPSHa is calculated at suction nozzle of pumps.
2	Please specify any requirement of minimum submergence for pump in your design based on level setting.	Refer to above response, vendor shall specify minimum submergence for pumps accordingly.
3	Please clarify any boot is consider to provide static head for this pump	No boot is considered for static head, however, vendor shall provide adequate system for smooth pumps' operation.
4	Please elaborate what would be vapour pressure, when suction condition will be 80 psia.	Vapour pressure shall be considered same as suction pressure and liquid properties mentioned in datasheets is for understanding of liquid behavior.
5	Please clarify what would be suction condition when vapour pressure is 17.6 psia (min). If suction pressure is also same due to saturated condition then why 80 psia suction pressure is considered in rated condition instead of 17.6 psia.	Refer to above response of point No.4
6	Please share vessel GA or datasheet so that pump rod (length) and submergence to be checked/selected.	Refer to above response of point No.1
7	Please share P&ID so to evaluate above stated concerns and properly select the pump.	Stuffiest information is provided for bidder to quote the pumps, whereas, P&ID shall be provided to successful bidders=.

