

**PROCUREMENT (SUPPLY), CONSTRUCTION, INSTALLATION/ERECTION, PRE-COMMISSIONING, & COMMISSIONING ASSISTANCE FOR NEW CENTRIFUGAL COMPRESSORS AND MODIFICATION WORKS OF EXISTING TURBO COMPRESSOR TRAINS FOR QADIRPUR COMPRESSION PROJECT**

**TENDER ENQUIRY NO. PROC-FC/CB/PROJ/QP-4369/2019**

**POST-BID CLARIFICATION No. OGDCL-QP-4369-003**



| Sr. No. | Bidder Query   | OGDCL/ENAR Response (11-Oct-2019)   |
|---------|--|---|
| 1       | Refer to BOQ –M2A, PS-304A, please confirm that the supply of paint material will be in bidder scope from description it appears that only application is in bidder scope.   | The referred BOQ heading (BOQ-M2A, PS-304A), clearly indicated that supply is included in Bidder's scope. Accordingly Bidder is required to quote considering supply and application basis.   |
| 2       | Please let us know about tentative duration for Shutdown.  | Shutdown period varies from 2-7 days depending on the downstream gas requirements and GoP Instructions. However, Bidder is required to Plan the activities in such a way that minimum works will be required in shutdown period, which will be mutually agreed during execution.  |
| 3       | Please Provide us the Estimated Delivery date of all 3 Compressors.  | Delivery date of compressors will be shared with successful Bidder, however, delivery dates of compressors are not currently on critical path of the overall project schedule.  |
| 4       | Refer to BOQ # 0220-GA-8001-03A-0 (BOQ-M2A), PS-303A, The Title of the BOQ is "Supply & Installation of Steel Structures" While the description below the Title not covering Supply. The same case in BOQ –M2B, PS-306B. Please Confirm that Supply of Steel Structure is in Contractor Scope? | Yes referred BOQ –M2A, & M2B , includes supply and installation of steel structure in contractor scope.   |
| 5       | Refer to BOQ # 0220-GA-8001-05 (E2-Electrical installation), PS-506A, Item # 5, Please Provide the Existing Lighting Protection Material List to Evaluate the Short Comings if any.  | Lightening Protection Material List is not available. Bidder to estimate the work based on site visit / its own experience for such installations. Only dismantling and relocation works are required with minimum rectification works (if any) with new material is in scope of Bidder. Bidder to quote on lump sum basis. |
| 6       | Refer to BOQ # 0220-GA-8001-05 (E2-Electrical installation), PS-503, NOTE # 3, Please confirm if the civil foundation for motor & Motor Control Station has been covered in civil BOQ and this BOQ shall quote only for the installation of equipment.   | Civil foundation for pump/cooler along with motor is covered in Civil BOQ. However, civil work required for motor control station is covered in electrical BOQ.   |
| 7       | Refer to electrical and instrument BOQ's we understand that all civil works (foundations etc / quantities) related to E&I equipments has been covered in the civil BOQ, please confirm.  | Civil works required for E&I works is covered in E&I BOQs respectively. Please refer each PS of respective E&I BOQ.   |
| 8       | Refer to civil SOW, please clarify dewatering scope if any shall cover which BOQ?.   | Dewatering is in Contractors scope and must be considered as per SOW and relevant specification wherever required. BOQs already covered dewatering efforts and rates must be quoted accordingly.  |
| 9       | Refer to DWG# 0106-CD-7301-(R2), Note # 15, please clarify the dismantling scope.  | Dismantling / demolition works as mentioned in notes and SOW shall be considered and Bidder to quote as per relevant BOQ item for the Demolition works.   |
| 10      | Please clarify the location and size of pump foundation.   | Location of the pumps are shown in plot plan, for size / quantity, Bidder to consider the relevant BOQ to quote.  |
| 11      | Please provide the NGL so to evaluate the extent of excavation.  | Bidder to consider the relevant BOQs for the excavation works.  |

**PROCUREMENT (SUPPLY), CONSTRUCTION, INSTALLATION/ERECTION, PRE-COMMISSIONING, & COMMISSIONING ASSISTANCE FOR NEW CENTRIFUGAL COMPRESSORS AND MODIFICATION WORKS OF EXISTING TURBO COMPRESSOR TRAINS FOR QADIRPUR COMPRESSION PROJECT**

**TENDER ENQUIRY NO. PROC-FC/CB/PROJ/QP-4369/2019**

**POST-BID CLARIFICATION No. OGDCL-QP-4369-003**



| Sr. No. | Bidder Query   | OGDCL/ENAR Response (11-Oct-2019)   |
|---------|--|---|
| 12      | Refer to BOQ –E2, PS-505, Note # 4, (The installation cost shall be inclusive of the supply of all installation material although not specified in BOQ without any extra cost.), Please clarify. | The Bidder shall consider the supply of all the construction material either major or minor which shall be required for the installation of respective electrical item in a satisfactory manner and as per tender scope and specifications. |