

Clarification No. 01

TENDER ENQUIRY NO. PROC-SERVICES/CB/P&P-4386/2019. HIRING OF GAS GENERATORS ON RENTAL BASIS AT QADIRPUR RESIDENTIAL CAMP.

One of the Prospective bidders have made a few queries against the subject Tender Enquiry. The queries along with OGDCL replies are given below for information of all the prospective bidders.

S.No	Clarification/Query	OGDCL REPLY
1	1) Page 1 Clause 3 – Contract Period: Is the usable period mentioned (April to September) confirmed 06 months deployment and the contractor will be paid for these 06 months only? Secondly April to September means, you will need generators under this tender in 2020, as tender process normally takes 3 to 4 months' time.	Yes, the contract period is confirmed i.e April to September, If the same period passes in 2019 then of course next period will start in 2020.
2	2) Clause 4.3 and Technical Qualification Marking Criteria # 06: Bidders providing generators older than 05 years will get zero and hence will be technically disqualified. We request you to please allocate some marks to older units also, like it is mentioned in very recent tender enquiry <u>PROC-SERVICES/CB/PE&FD-4352/2019 - Hiring of Rental Services for Gas/Diesel Engine Generators.</u> In this tender OGDCL allocated some marks to the older units, so that fair chance is provided to the bidders and to discourage presentation of misleading information and fake data plates.	Clause 4.3 may not be changed, so please provide your quotation as per tender documents (SOR).
3	3) Similarly Technical Qualification Marking Criteria # 02 states that if you have provided less than 03 generators of capacity greater than 600 kW, the bidder will get zero and hence that bidder will be disqualified. Our company is providing rental generator services to OGDCL for more than a decade now. Majority of the rental gas generators in OGDCL are ranging from 100 kW to 500 kW and we are providing the services in this range. Moreover, in the above mentioned tender (4352) also, one 600 kW generator is required on rental basis and Marking Criteria is not restricting bidders for KW rating related to past experience with OGDCL. Please refer back to the tender <u>PROC-SERVICES/CB/P&P-3122/2017,</u> for the hiring of gas generators for Qadirpur Plant, where we went for Grievance Committee. We believe that	As the requirement is of 800 KW so Marking Criteria # 2 is justified, please quote as per tender documents (SOR).

	<p>this time also the TOR terms are designed in such a manner that it favors only one supplier who is currently enjoying benefits being single party winner in the mentioned tender</p>	
4	<p>4) Clause 4.1.6: Supply of 150 meter standard 4 core power cable; we believe this will have a significant effect on rental calculations and its rental should be mentioned separately in the financial bid. This may be termed as mandatory for all the bidders.</p>	<p>Cable is required along with Gensets and the requirement of Gensets is complete package basis, so please quote as per tender documents (SOR).</p>
5	<p>5) Clause 4.14.3: Only fuel will be provided by OGDCL. What about cooling water for cooling tower? Currently OGDCL is providing cooling water to the existing rental generators at Qadirpur Plant.</p>	<p>Cooling water will be provided by OGDCL.</p>