

TENDER ENQUIRY NO. PROC-FC/CB/P&P/KPD-4417/2019 FOR REFRIGERATION COMPRESSOR SPARES FOR KUNNER PLANT

Sr.No	Query	Response from OGDCL
1	<p>Could you kindly check with End User which refrigerant using: Ammonia OR Propane?</p> <p>Depends of refrigerant, parts can be different.</p> <p>Also, please send us data sheet that can prove which refrigerant using if available at end user side.</p>	<p>OGDCL:</p> <p>The propane is being used as refrigerant in the compressor.</p> <p>Furthermore compressor model 2520 LSC-51 & Serial No. 2521416 has been already mentioned at SOR. Supplier may refer the same.</p>