

Pre Bid Clarification # 1 Against Tender Enquiry # PROC-FE-CB-P and P-QP-4452-2019- Spares for Fire & Gas Detection System

Sr #	Description	Question	OGDCL Reply
01	DETECTOR GAS CH ₄ , DET-TRONICS PIRECLA14A1T1, APPROVALS SIL/FM/ATEX/CSA OR EQUIVALENT IP 1078325-7	Please confirm that they need infrared sensor or if it is ok also catalytic sensor? Please confirm if the detector must be in stainless steel or it is ok also aluminium?	Infrared sensor and stainless steel
02	MSA ULTIMA PART A-ULTX-PCB-E-E-1-0-0-0 transmitter ULTIMA XE SERIES	For which gas it is? Is it ok aluminium enclosure? Or they need stainless steel enclosure?	Methane and Stainless steel
03	MSA ULTIMA PART A-ULTX-SENS-31-1-CC ULTIMA XE SERIES	For which gas it is? Is it ok aluminium enclosure? Or they need stainless steel enclosure?	Methane and Stainless steel