

### Clarification #01 - OGDCL COOLING TOWER

<b>Project Name:</b>	Design&Supply of Cooling Towers(Complete Package)Including Installation/Comissioning Assistance at Dakhni Plant	
<b>Tender No.:</b>	PROC-FC/CB/P&P/DKN-4612/2020	
<b>Customer:</b>	M/s OGDCL	
<b>Vendor:</b>	Jereh Oil & Gas Engineering Corporation	
ITEM	JEREH's Question	OGDCL's Reply
1	<p>1.Type Selection We noticed that there is no specific stipulation on the type of cooling tower :Opening cooling tower or Closed cooling tower? If we are understanding correctly , any one of the above can be used as long as the type to be selected could satisfy the specification requirements. Please confirm this point.</p>	Type of cooling tower is induced draft open or close is not necessary meet the required design parameters
2	<p>Cooling Tower Drawing. The drawing given in the Tender is draft cooling tower. But we recommend induced draft mechanical cooling tower as currently it is more widely used. Please confirm if we could use Draft Mechanical CoolingTower in this project</p>	Type of cooling tower is mentioned in the TOR i.e Induce Draft (Cross Flow/Counter Flow). Drawing is for only foundation reference.
3	<p>Evaluation Criteria On the 5th Page of the Tender, It is saying "Note :Financial evaluation will be against Sr#01&amp;02 only" So if we are understanding correctly ,"02 years spares " on the form of "Schedule of Requirement "will not be considered into the financial evaluation . Please confirm this point .</p>	Commissioning spares are the part of Sr#01 however the 02 years spares cost willnot be the part of the financial evaluation. List of commissioning and 02 year spare must be provided the technical bid.
4	<p>Work Scope The bidder is required to provide" Installation and Commissioning Assistance at Dakhni Plant". Please clarify what sort of assistance needs to be provided and work scope of this assistance.</p>	Bidder must provide their engineer at the time of installation and commissioning for assistance.
5	<p>The No.s of Man-day To Be Provided The bidder is required to provide" Installation and Commissioning Assistance at Dakhni Plant". Please advise the No.s of days and workers needed during the "Installation and Commissioning Assistance at Dakhni Plant"</p>	Installation and commissioning assitance on lump sump basis not on Man Days Basis. Bidder should submit the proposal on lump sump basis.