

CLARIFICATION # 01

TENDER ENQUIRY NO. PROC-FC/CB/P&P/DKN-4612/2020

Bidder Clarification	OGDCL Response
Bidder ask for the change of type of cooling tower as counter flow instead of the requirement as cross flow	In our case both can fill our purpose. For healthy and better competition we can accept the type of flow as counter

M Ahsan Waqar Khan
J.E (Mech.)-North B

Khalid Iqbal Malik
Manager (P&P) North B