

TENDER ENQUIRY NO. PROC-FC/CB/P&P/DKN- 4612/20 DESIGN AND SUPPLY OF 03 NO'S OF COOLING TOWERS

Sr.	Reference	Description in Tender Documents	Kelgary's Queries	OGDCL's Response
1	Clause 22, Page 3, Terms of References	Bidders must have 10 years' experience of supply of spare parts, submit their company profiles, experience for supply of such spare parts (i.e Previous Purchase Orders) along with technical bids.	We understand that the Bidder or Packager or Manufacturer should have 10 years' experience of supply of spare parts rather than only Bidders. Please confirm.	The bidder must have also 10 years experience
2	No. 5, Page 4, Technical Evaluation Criteria	PEC Registration	As per our understanding, Scope of work includes Design & Supply & Installation/ Commissioning Assistance on C&F Karachi basis therefore, PEC Certificate is not required, accordingly. Please confirm.	PEC registration is required however any bidder can qualify without PEC Certification.
3	Design Basic	/	Please provide the Raw Water Specification / Circuit Water Specification to select the packing material of cooling tower.	Conductivity = 843MS/cm. TDS = 462mg/L. Total Hardness = 190ppm. Ca Hardness = 120ppm. Total Alkalinity = 108ppm. Chlorides = 42ppm. Turbidity = 1.0 NTU.