

**TENDER INQUIRY PROC-FC/CB/P&P/DKN-4682/2020 PROCUREMENT OF NEW INSTRUMENT
AIR COMPRESSOR ALONG WITH DRYER PACKAGE**

Sr.	Query	Response from OGDCL
1	Which type of screw compressor is required? Oil-injected or oil-free?	Screw Compressor is Oil Flooded Type.
2	Which is the required Air quality class according to ISO8573?	Required Air is for Oil and Gas Plants instrumentation.
3	Is the installation area safe or hazardous? (electric motor and PLC panel are required for hazardous area but often the installation area is safe but the electrical classification is for hazardous area)	Motor and PLC details are given in TOR
4	Is cooling water available?	Cooling water is available at site.