

Subject : Bid Clarification Against Tender PROC-FA/CB/P&P/ KPD-4931/2020 Air Intake Filters for Gas Turbines.

1. Reference to the attached e-mails from different bidders (three numbers) for the post bid clarification against tender No. PROC-FA/CB/P&P/ KPD-4931/2020 for procurement of air intake filters for gas turbines. The reply of clarification is under;

Sr. No	Bidders Query	OGDCL reply
01	Provide the part number of the required intake filters in order to fully comply with the specifications.	The filters are consumable items & every manufacturer allocate its own part number. The technical detail, specifications & dimensions needs to be complied instead of part number. However, the old detail of the filter supplied along with Gas Turbines is as under; Manufacturer of filter supplied along with Gas Turbines: M/s Wuxi China Product: SYbj-21-lx, Specification / Type: GHL-20-h,
02	The attached photo in the tender document is too vague, and we cannot check clearly the dimension's scope. Can you ask for the original photo?	Attached.
03	First page schedule of requirement indicates quantity: 476 pcs – while page 3 at 2. SCOPE OF SUPPLY on 2.1 Intake and ventilation air filters.....Total Quantity shows 595 Numbers. Please clarify.	The total required quantity of gas turbine air filters is 476 numbers as per first page schedule of requirement.

