

CLARIFICATION AGAINST TENDER# PROC-FC/CB/P&P/KPD-5049/21 HYDRAULIC AERIAL TUBE BUNDLE EXTRACTOR FOR KPD-TAY PLANT

Sr.	Query	Response from OGDCL
1	<p>SOR carries little information /specs. for prime mover required. We understand more detailed specifications are needed for proper selection.</p> <p>Also we understand trailer / rack for carrying/ movement of Tube bundle along with Prime mover would also be required.</p> <p>Prime mover in our opinion has a cost which is not reflected in the amount of Bid money mentioned.</p> <p>We need your guidance to reach at correct equipment selection</p>	<p>The mentioned Prime mover is diesel engine for the operation of Hyaulic system of tube bundle extractor. No trailer for movement of bundle extractor is required hence it not mentioned in the TOR. The provided specification of diesel engine & bundle extractor are sufficient to select the Hydraulic Ariel Tube Bunuel Extractor operated by diesel engine as mentioned.</p>