

TENDER NO. PROC-FE/CB/PE&FD-5122/2021

H2S Gas Detectors for Uch-1

Clarification No. 03

Sr. No.	Bidder's Query	OGDCL Reply
1	Accessories like dead plugs, cable glands are not required?	No
2	Built-in magnetic user interface is demanded, whereas please confirm if infrared remote user interface for selection of mode is also acceptable?	Acceptable