

Ref: Clarification#1

Dated: 26.11.2021

SUBJECT: CLARIFICATION PRIOR TO BID PROC-FE/CB/P&P/DKN-5190/2021


Query raised by prospective bidders:

Query:

- i. "As per SOR, you need BRACKET TYPE-P FOR ROD DIA 1-1/2" Do you need pole as well for bracket?"
- ii. "Kindly provide some details about lamp. There is no detail about lamp in SOR".

Reply:

- i. **Only bracket of described type and dimension is required and pole is not required.**
- ii. **Lamp detail is already given in SOR that is 2x18 WATT LED, 230 V, 50Hz.**


26/11/2021
AHMED ZIA
Dy. Chief Engr. (ELECT)
P&P-N, Ext: