	weld).		
	of the pipe wall (including the		
	test must be carried out for more than		
information available.	hydrostatic test, the final electromagnetic		
Please refer to the TOR (Term of Reference) and quote as per requisite	After the wall thickness condition of	r.r	L
information available.	equivalent test method)		
Please refer to the TOR (Term of Reference) and quote as per requisite	Bend test (as per ASME sa-53 or	11.8	9
	method)		
	rest frame or equivalent test		
incorporated in TOR.	MTSA of gariooos) (noisegnole bas fimil		
No need to change as "or equivalent "test method has already been	Tensile strength (yield strength, tensile	9.2	ς
	rest method)		
incorporated in TOR.	(according to ASTM e-1268 or equivalent		
No need to change as "or equivalent "test method has already been ov.		2.2	Þ
	(HFI) welding instead of Laser welding.		

and the same of th

OIL & GAS DEVELOPMENT COMPANY LIMITED CEMENT & STIMULATION DEPARTMENT ISLAMABAD

CLARIFICATIONS ADDRESSED AGAINST

TENDER ENQUIRY NO. PROC-FE/CB/STIM-5437/2022

With refer to the pre-bid queries by the Bidders via emails for the subject Tender Enquiry, reply for the clarifications is mentioned as under:

Sr.No.	TOR Clause	Query by the bidder	OGDCL Reply
1	2	Is OGDCL looking for a True Taper design as the RFQ description states? If so, the design they have suggested is not True Taper. Please clarify.	As per TOR at clause 02, a true taper tubing is recommended. However, the length segments mentioned in TOR (clause02) are considered as cancelled. Wall Thickness range should be (Upper side = 0.175" – Bottom end or BHA end = 0.135"). Bidder will be confirmed the length segments in their Bid for True taper design.
2	2.6	Are these working reels OGDCL is looking for or just shipping spools for the strings?	Only a shipping spool is required as per TOR.
3	5.14 & 5.15	Tubing string should be processed based on the concept of forming a weld seam by electric resistance or electric induction	i details is being recommended/standard