

CLARIFICATION NO. 01

TENDER ENQUIRY NO: PROC-SERVICES/CB/C&ESS-640000093/2022

HIRING SERVICES FOR CONSULTANCY SERVICES FOR DESIGNING OF RCC WORKSHOP SHEDS WITH STEEL TRUSS ROOF FOR MECHANICAL, ELECTRICAL & INSTRUMENT SECTION INCLUDING OFFICES AND ASPHALTIC ROADS AT NASHPA LPG PLANT.

Following points are clarified for the information of all prospective bidders:

- i. Topographic survey is only limited to the plot of the proposed sheds with orientation / location with respect to overall plot of the plant & camp. Further marking of the existing boundary wall on all four sides in the required topographic sheet of the plant & camps area will also be included.
- ii. As built drawings are not included in consultant scope.
- iii. The consultant shall decide the no of bores for geo-technical investigations in their visit to site prior to bidding. It shall not be less than 02 no of bores for each shed (Minimum no of bores for all three shed is 06). The cost "as per number of bores decided by the consultant" may be included in his quoted cost accordingly.