

Ref: Clarification/Amendment # 1

Dated: 20.01.2023

SUBJECT: PRE-BID CLARIFICATION FOR TENDER NO. SER/CB/P&P-6400000116

(HIRING OF GENERATORS ON RENTAL BASIS FOR WALI FIELD)


Query raised by prospective bidders:

Query:

- i. What will be the actual length of power cable required to connect the Gensets to Changover Panel?

Reply:

- i. **Refer to clause 4.1.6 of tender notice, the required distance mentioned as 250 meters. This is a typo mistake, therefore, consider it as distance of 50 meters upto the changover panel and cable length shall be appropriate to accommodate that distance.**


AHMED ZIA
Chief Engr (ELECT) P&P
Ext 4160