

Hiring of PC Contractor Services for Procurement (Supply), Construction, Installation/Erection, Testing & all Complete Civil, Mechanical, Electrical and Instrumentation Works and Provide Pre-Commissioning, Commissioning, Startup & Performance Testing Activities For Jhal Maqsi Development Project

TENDER ENQUIRY NO. OGDCL-SCM-CB-PROJ-JM-40000564-2023

PRE-BID CLARIFICATION No. OGDCL-JM-005



Sr. No.	Reference Section	Bidder Query	OGDCL/ENAR Response (05-04-2023)
1	0102-PA-2003-2 (Piping Specification)	Please share valve specification document # 0102-PA-2008 as referred in piping specification point G.	Please find attached Valve data sheet # 0102-PA-2008.
2	0102-DS-1732-1 (Drinking Water Package)	The water quality report attached in provided datasheets are of year 2013. Please provide latest water quality report . Further, please confirm the required plant capacity as only consumption of water cooler is mentioned in provided datasheets.	1. The only available water quality report of 2013 is attached in datasheet. Bidder to consider the same. 2. The minimum requirement of "DRINKING WATER" consumption is already mentioned in datasheet i.e.50L/Day. Further Bider to know that no design is required from Contractor, therefore, questions are irrelevant.
3	0102-ELA-6556 (Specifications for CP System)	Please share piping layouts for Oily water and Fire water lines	Please find attached Underground layout.
4	0102-GA-8001-04 Electrical BOQ PS-404	Please share the number and type of bends required for Electrical cable trays.	PC Contractor is responsible to quantify the required number and type of bends (i-e horizontal/vertical tees, outside/inside vertical risers, horizontal elbows etc.) from submitted tender drawings.
5	0102-GA-8001-06 Instrument BOQ PS-605	Please share the number and type of bends required for Instrument cable trays.	
6	Missing Electrical Documents	Please share following missing electrical documents 1. 0102-ELA-6531 2.0102-ELA-6505 3.0102-ELD-6725 4.0102-ELD-6726	1. Already submitted. 2/3/4. Subject document/drawings shall be shared at later stage.