PROCUREMENT (SUPPLY), CONSTRUCTION, INSTALLATION/ERECTION, PRE-COMMISSIONING, & COMMISSIONING ASSISTANCE FOR NEW CENTRIFUGAL COMPRESSORS AND MODIFICATION WORKS OF EXISTING TURBO COMPRESSOR TRAINS FOR QADIRPUR COMPRESSION PROJECT

TENDER ENQUIRY NO. PROC-FC/CB/PROJ/QP-4369/2019 POST-BID CLARIFICATION No. OGDCL-QP-4369-024



Sr. No.	Bidder Query	OGDCL/ENAR Response (14-Nov-2019)
Electrical & Instrumentation		
1	With reference to Electrical & Instrument BOQ; there are mentioned in notes that 'vendor having experience in supply of at least 03 nos. of OGDCL major projects / facility'. Please clarify there are some reputable vendors having good reference list but not supplied instruments/equipments to OGDCL can be acceptable to OGDCL. Please advise.	Please note that E&I material shall be only supplied from the vendor having experience of at least 03 nos. of OGDCL major projects / facility. Bidder to adhere the tender requirement.
	Refer to modification in existing DCS system, the vendors for I/O cards not able to provide the cards as the existing DCS system is obsolete. Can we provide the stand alone system of the recommended I/O;s. Please advise.	Stand alone system is Not acceptable. Furthermore to our knowledge Existing DCS System is not Obsolete. Existing DCS System is ABB Model # AC800M having I/O modules Model # S800. Therefore Bidder is requested re-check and provide/ supply as per tender requirement.