

SUBJECT: PRE-BID CLARIFICATION FOR TENDER ENQUIRY NO: 6300000110/SCM LOCAL/ 295 WALI GAS
PROC OIL AND FIELD / 2022

(SUPPLY OF ELECTRIC POWER CABLES FOR WALI PLANT)

Query raised by prospective bidders:

Query:

- i. Clarity/ elaboration of specification required for some cables.

Reply:

- i. **All prospective bidders are requested to note the following clarifications for specs, serial wise , against subject tender:**

S#	SPECIFICATION OF POWER CABLES	Qty (meters)
1	CABLE 120 MM2 4-CORE ,COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	80
2	CABLE 70 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	500
3	CABLE 50 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	500
4	CABLE 35 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	500
5	CABLE 25 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	1800
6	CABLE 16 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	1000
7	CABLE 10 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	1000
8	CABLE 6 MM2 4-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	800
9	CABLE 2.5 MM2 2-CORE COPPER, CU/PVC/PVC/SWA/PVC,600/1000 V	500



AHMED ZIA

Chief Engr. (ELECT)
P&P-N, Ext