PROC-FB/CB/PROD-4884/2020

Wellhead Control Panels

TECHNICAL CLARIFICATION # 03

S#	Query	OGDCL Reply
1	Since downstream air pressure of S3 solenoid valve will be released through SRV2, therefore shuttle valve will be required in between S3, POV3 & SRV2/POV1 to meet the functional requirement of opening of SSV remotely through S3. Bypass Valve SRV2 SRV2 SHV POV1 POV1 POV3 POV3	Since all functional performance warranties & guarantees rests with the vendor, therefore it is essential to meet the material functionality as per tender specs. So for better material functionality, inclusion of shuttle valve is acceptable.
2	Quantity of needle valve in pneumatic section was mentioned as 07 in BOM vide clause 11.1.23 while its quantity was 08 in the diagram.	Quantity of needle valve mentioned in the BOM vide clause 11.1.23 "Needle valve on pneumatic loops (N1), NACE, 500 psi" has been amended & read as Qty: 08