



UCH COMPRESSION PROJECT



Design Engineering, Procurement (Supply), Construction, Installation/Erection, Pre-Commissioning, Commissioning & Start-up (including performance testing and Reliability Guarantee Test) of UCH Front End Compression Project

Tender Enquiry No. PROC-FC/CB/PROJ/UCH (COM)-5155/2021

Pre-Bid Clarification-17

Sr. No.	Tender Document Reference	Description	OGDCL/ ENAR Response (11-Jan-2022)
1	Scope of Work Section 2.6	<p>Under bullet 'Flare System of UCH-I and UCH-II', It is mentioned that:</p> <ul style="list-style-type: none"> - Addition of a new flare knockout drums along with associated pumps of similar capacities as installed at UCH-II existing Plant. - Replacement of Flare stack and flare tip package with higher size diameter of 56 inch. <p>Bidder understands that these items are not part of this Tender scope and will be dealt separately afterwards by Client.</p> <p>In case, these items are required to be supplied, then please provide the datasheets of these items (flare KO Drum, Associated Pumps & Flare Stack /Tip Package).</p>	<p>Bidder understanding is not correct. The referred modification in existing flare system is in bidder's scope.</p> <p>Also, please refer Sec.1.1.11 of Appendix-C (Bid Price Schedule) in this regard.</p> <p>For Flare KO drum and pumps datasheets, please refer Annexure-VII & VIII of Doc. No. 0221-A-1001-2 (Basis of Design) which is already part of tender document. Also, size of flare stack/tip is already mentioned in SoW which shall be further finalized during detailed engineering stage by EPCC Contractor.</p>
2	Pre-Bid Clarification-14 Sr. No. 18	<p>As per client response against Pre-Bid Clarification-14 Sr. No. 18, it is specified that "maximum supplies & engineering in this respect are already mentioned in tender. Please specify the maximum supplies scope that is required to be executed by bidder as no datasheets, BOQs etc. is available in Tender documents related to this scope. Only tie-in of new FEC facility with UCH-I & UCH-II flare headers is defined & specified in tender documents. Please clarify the maximum supplies scope.</p>	<p>Supplies w.r.t. UCH-II flare system is already mentioned (please refer above response). However, EPC Contractor is responsible for detailed engineering and provision of supplies/services to achieve the tender requirements.</p>
3	Clause C of "Instructors to Bidders" [Sheet 11 of 36]	<p>Referred clause mentions that "The lead partner shall be authorized to incur liabilities and receive instructions for and on behalf of any and all partners of the joint venture/consortium and the entire execution of the Contract. All the payment shall be made by OGDCL in the name of lead partner".</p> <p>In order to avoid the impact of double taxation, please clarify whether the consortium partners can raise direct invoices and receive payment there against in respect of their respective scope of work / division of responsibilities, stipulated in the MOU among them.</p>	<p>Not acceptable. Bidder to strictly adhere with the tender requirements</p>



UCH COMPRESSION PROJECT



Design Engineering, Procurement (Supply), Construction, Installation/Erection,
Pre-Commissioning, Commissioning & Start-up (including performance testing and Reliability Guarantee Test) of UCH Front End Compression Project

Tender Enquiry No. PROC-FC/CB/PROJ/UCH (COM)-5155/2021

Pre-Bid Clarification-17

Sr. No.	Tender Document Reference	Description	OGDCL/ ENAR Response (11-Jan-2022)
4	Clause 3.2.1.1 (ix) of "Instructors to Bidders" [Sheet 17 of 36]	<p>In the light of the Clause 3.2.1.1 (ix) of "Instructors to Bidders" [Sheet 17 of 36] regarding the submission of the Bid Bond:</p> <ul style="list-style-type: none">- Please clarify whether the consortium partners can submit the Bid Bond equivalent to respective share in the consortium (according to scope of work / division of responsibilities, stipulated in the MOU among them) to save the financial charges for issuance of back to back bank guarantees.- Similar query is for submission of Performance Guarantee (PG) and Advance payment Guarantee (APG) at later stages of contract.	Not acceptable. Bidder to strictly adhere with the tender requirements
5	DOC NO: 0221-PA-2003 REV 0, "SPECIFICATION FOR SKID MOUNTED EQUIPMENT ACKAGES" Section 5.8 "Instrumentation"	<p>All instrumentation and controls shall be furnished in accordance with the requirements of the Project Specification for Control System Design Basis & Specification doc#0221-IMA-6001.</p> <p>Company to provide missing document in tender Control System Design Basis & Specification doc#0221-IMA-6001.</p>	<p>It is typo mistake in the referred document no. (0221-IMA-6001). Please refer the correct Document i.e. 0221-IMA-6000-0 (Specification for General & Packaged Instrumentation) which is already part of tender.</p>