



**KPD-TAY COMPRESSION PROJECT**  
Tender Enquiry No.: PROC/FC/PROJ/KPD-TAY/COMP/5313/2022  
**PRE-BID CLARIFICATION # 17**



One of the bidder has asked following queries, OGDCL/ENAR's response is as follows:

Sr. No.	Tender Documents Reference	Bidder's Query	OGDCL/ENAR's Response
1	<p><u>CIVIL Building</u></p> <p>CCR on Drawing 0258-CD-7102 Operation Room on Drawing 0258-CD-7103 Work Shop on Drawing 0258-CD-7306 Living Facility on Drawing 0258-CD-7308 GUARD ROOM on Drawing 0258-CD-7309 OFFICE BUILDING on Drawing 0258-CD-7311 SWITCHGEAR/MCC ROOM on Drawing 0258-CD-7312 CCR/UPS ROOM on Drawing 0258-CD-7319 PRAYER HALL on Drawing 0258-CD-7202 GUARD ROOM on Drawing 0258-CD-7203 Work Shop on Drawing 0258-CD-7204 SWITCHGEAR/MCC ROOM on Drawing 0258-CD-7206</p>	<p>Please clarify the Air Conditioner for the below buildings and whether the split-type AC is enough or not if need. Which one shall be facilitated with ventilation equipment.</p> <p>CCR on Drawing 0258-CD-7102 Operation Room on Drawing 0258-CD-7103 Work Shop on Drawing 0258-CD-7306 Living Facility on Drawing 0258-CD-7308 GUARD ROOM on Drawing 0258-CD-7309 OFFICE BUILDING on Drawing 0258-CD-7311 SWITCHGEAR/MCC ROOM on Drawing 0258-CD-7312 CCR/UPS ROOM on Drawing 0258-CD-7319 PRAYER HALL on Drawing 0258-CD-7202 GUARD ROOM on Drawing 0258-CD-7203 Work Shop on Drawing 0258-CD-7204 SWITCHGEAR/MCC ROOM on Drawing 0258-CD-7206</p>	<p>Split type ACs shall be provided in all new buildings as per Buildings General Arrangements (G.A). The bidder shall provide calculations for Air conditioning system for new buildings or porta Cabins in this regard.</p>