ENAR	**DATA SHEET FOR** **3.5 KILOGRAM, CO2 FIRE EXTINGUISHER**	Spec. No.	0102-DS-1775
		Prep. By ZAH	Appr. By MSL
		Date	18-Oct-12
		Sheet 1 of 1	Rev. 0

Client: OIL & Gas Development Company LTD.
Unit: Fire Water System
Plant: Gas Plant Development Project
Order No.:
Req. No.:
Job No. : 14-0102
Vendor:
Model No.:
Vendor Dwg. No.:

Item	Description	Specific Requirements
1	Quantity	Ten(10)
2	Type	Stored Pressure
3	Rating	5B:C
4	Agent	Carbondioxide
5	Agent Brand	Vendor to specify
6	Agent Capacity	3.5 Kg
7	Pressure Indicator	Required
8	Hanger	Wall Type Required
9	Cover	Required
10	Special Tools & Accessories	Vendor to specify
11	Controllable on / off Disch.	Required
12	Operation	Squeeze Handles
13	Cylinder Material	Stainless Steel
14	Overall Height	Vendor to specify
15	Body Diameter	Vendor to specify
16	Overall Mass	Vendor to specify
17	Operating Pressure	200 psig
18	Discharge Hose	Reinforced PVC
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		