ENAR	**DATA SHEET FOR** **2½ GALLON WATER FIRE EXTINGUISHER**	Spec. No.	0102-DS-1781
		Prep. By ZAH	Appr. By MSL
		Date	18-Oct-12
		Sheet 1 of 1	Rev. 0

Client: OIL & Gas Development Company LTD.
Plant: Gas Plant Facility Project
Req. No.:
Vendor:
Vendor Dwg. No.:

Unit: Fire Water System
Order No.:
Job No. : 14-0102
Model No.:

Item	Description	Specific Requirements
1	Quantity	Nineteen (19)
2	Type	Stored Pressure
3	Rating	2-A
4	Agent	Water
5	Agent Capacity	2½ Gallons (9 Litres)
6	Pressure Indicator	Required
7	Hanger	Wall Type Required
8	Cover	Not Required
9	Special Tools & Accessories	vendor to specify
10	Controllable on / off Disch.	Required
11	Operation	Squeeze Grip Control Head
12	Cylinder Material	Stainless Steel
13	Overall Height	vendor to specify
14	Body Diameter	vendor to specify
15	Overall Mass	vendor to specify
16	Operating Pressure	100 psig
17	Discharge Hose	Reinforced PVC
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		