

## PROCUREMENT OF VALVES FOR KPD-TAY PLANT

TENDER # PROC-FC/CB/P&P/KPD-TAY-5366/2022

PRE-BID CLARIFICATION No. 03-A DATED 31.05.2022

In continuation of Pre-Bid Clarification No. 03 dated 31.05.2022, the following two OGDCL replies at serial # 5 & 7 (only) mentioned in said clarification are to be **READ AS** given below:

Sr. No.	Bidder Query	OGDCL Reply
5	VB-201: Operator: Lever (Gear over 8"): we suggest Gear for 8" and above, as the lever length of 8" will be out of standard.	As per TOR, lever operator is required. However, any bidder/manufacturer offering gear operation instead of lever shall also be acceptable.
7	VB-211: Operator: Lever (Gear over 8"): we suggest Gear for 4" and above, as the lever length of 4" will be out of standard.	As per TOR, lever operator is required. However, any bidder/manufacturer offering gear operation instead of lever shall also be acceptable.