

TECHNICAL EVALUATION REPORT

RFP NO.: OGDCL-SCM-FD(LOCAL)-CB-PNP-235562621-2024

DESCRIPTION OF THE RFP: SPARES FOR FIRE AND GAS SYSTEM FOR QADIRPUR

TECHNICAL BID OPENING DATE: 01-04-2024

S. No.	Name of Bidder	Status (Technically Responsive/ Non- Responsive)	Remarks (Reasons of Rejection)
1	M/S Potentia Engineering Pvt, Ltd	Technically Responsive	NA
2	M/S Solution Engineering Pvt Ltd	Technically Non - Responsive	Item # 1 only PCB are required instead of complete Gas Detectors. Item # 5,6 and 11: Only Sensors are required instead of complete detectors. OEM certificate from M/S Det tronics for equivalent not provided as per clause 4 of TOR.
3	M/S Shaheen Aerotraders	Technically Responsive	NA
4	M/S Tameer Inc	Technically Responsive	NA

Note:

1. Bidder may submit grievance within Seven (07) days of announcement of Technical Evaluation Report.
2. The grievance if any shall be sent to bgrc@ogdcl.com as per format available on OGDCL website.