



**OIL & GAS DEVELOPMENT COMPANY LIMITED**  
**PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD**  
**SCHEDULE OF REQUIREMENT**

**Material :PRESSURE, TEMPERATURE & DIFFERENTIAL PRESSURE  
 TRANSMITTER FOR UCH & KPD FIELDS**

**Due Date:**

**Tender Enquiry No: PROC/LD/PT/18681/22**

**Bid Bond Value : RS.1,000,000.00**

**Attachment(if any) : YES**

**EVALUATION WILL BE CARRIED OUT ON FULL**

Sr No	Description	Quantity	Make/Brand offered	Unit	Unit Price (PKR) Inclusive Of All Taxes Except GST	Unit Price (PKR) Inclusive of GST	Total Price (PKR) Inclusive of GST	Delivery Period Offered	deviation from Tender Spec. If Any
1	TRANSMITTER, SMART SCALEABLE COPLANAR DIFFERENTIAL PRESSURE P# 3051S1CD3A2A11A1BE5M5Q4Q8, RANGE:-1000 TO 1000 INCH H2O CAL.RANGE:0 TO 300 INCH H2O,WITH 5 VALVE MANIFOLD MODEL:0305RC52B11B4  ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	12		Number					
2	TRANSMITTER, SMART SCALEABLE COPLANAR PRESSURE P# 3051S1CG5A2A11A1BE5M5Q4Q8, RANGE: -14.2 TO 2000 PSIG,CAL. RANGE: 0 TO 1000 PSI,MIN. SPAN 10PSI,WITH 2 VALVE MANIFOLD MODEL :0305RC22B11B4  ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	18		Number					
3	TRANSMITTER, SMART TEMPERATURE WITH RTD,P# 3144PD2A1E5B4M5Q4XA, RANGE: -196 TO 300 DEG C,CAL. RANGE: 0 TO 150DEG F, RTD SENSOR MODEL :214CRWSMA1S3M0310SLE5UAE080XA ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	4		Number					
4	TRANSMITTER, SMART TEMPERATURE WITH RTD,P# 3144PD2A1E5B4M5Q4XA, RANGE: -196 TO 300 DEG C,CAL. RANGE: 0 TO 200 DEG F, RTD SENSOR MODEL :214CRWSMA1S3M0310SLE5UAE080XA ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	4		Number					
5	TRANSMITTER, SMART TEMPERATURE WITH RTD,P# 3144PD2A1E1B4M5Q4XA, RANGE: -196 TO 300 DEG C,CAL. RANGE: 0 TO 200 DEG F, RTD SENSOR MODEL :214CRWSMA1S3M0310SLE1UAE080XA ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	12		Number					
6	ENGINEERING ASSISTANT SOFTWARE PROGRAM FOR ROSEMOUNT 3051SMV, VERSION 6.5, LANGUAGE ENGLISH, USB PORT HART MODEM AND CABLES, LICENSE: SINGLE PC. MAKE: "ROSEMOUNT" OR EQUIVALENT.	1		Number					
7	FLOWCHECK 3 SOFTWARE, FLW CHK3, MAKE: "ROSEMOUNT" OR EQUIVALENT.	1		Number					
8	TRANSMITTER, SMART PRESSURE P# 3051S1TG4A2A11A1BB4I5M5Q4, RANGE: 0 TO 10MPa, SUPERMODULE SUPPLY:10.5 TO30VDC,OUTPUT:4-20mA,MWP: 4000PSI, WITH 2VALVE MANIFOLD MODEL:0306RT22BA11.MAKE: "ROSEMOUNT" OR EQUIVALENT.	2		Number					
9	TRANSMITTER, SMART TEMPERATURE,P# 3144PD2A2K5M5U1XA, RANGE: 0 TO 122 DEG C,CAL. RANGE: 0 TO 122 DEG C, SUPPLY	2		Number					



**OIL & GAS DEVELOPMENT COMPANY LIMITED**  
**PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD**  
**SCHEDULE OF REQUIREMENT**

Material : **PRESSURE, TEMPERATURE & DIFFERENTIAL PRESSURE  
TRANSMITTER FOR UCH & KPD FIELDS**

Due Date:

Tender Enquiry No: **PROC/LD/PT/18681/22**

EVALUATION WILL BE CARRIED OUT ON FULL

Sr No	Description	Quantity	Make/Brand offered	Unit	Unit Price (PKR) Inclusive Of All Taxes Except GST	Unit Price (PKR) Inclusive of GST	Total Price (PKR) Inclusive of GST	Delivery Period Offered	deviation from Tender Spec. If Any
	12-42VDC, OUTPUT 4-20mA, ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.								
10	TRANSMITTER, SMART SCALEABLE COPLANAR DIFFERENTIAL PRESSURE P# 3051S1CD2A2A11A1BI5M5Q4, MWP: 3626PSI,CAL RANGE: 0 TO 250 INCH H2O,WITH 5 VALVE MANIFOLD MODEL :0305RC52B11  ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	3		Number					
11	TRANSMITTER, SMART SCALEABLE COPLANAR DIFFERENTIAL PRESSURE P# 3051CD5A02A1AM5DFC6H7Q8, MWP: 3626PSI,CAL RANGE: 0 TO 250 INCH H2O, ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	1		Number					
12	TRANSMITTER, SMART SCALEABLE COPLANAR PRESSURE P# 3051CG5A02A1ADFM5C6Q8H7, RANGE: 0 TO 2000 PSIG,CAL. RANGE: 0 TO 2000 PSI, ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	4		Number					
13	TRANSMITTER, SMART SCALEABLE COPLANAR PRESSURE P# 3051CG4A02A1ADFM5C6Q8H7, RANGE: 0 TO 300 PSIG,CAL. RANGE: 0 TO 300 PSI, ASY INSTRUMENT. MAKE: "ROSEMOUNT" OR EQUIVALENT.	1		Number					

**Special Note:** The prospective bidders also download the master set of Tender Document

- The prospective bidders may keep in touch with OGDCL web site for downloading the clarifications/amendments (if any) issued by OGDCL.
- DELIVERY PERIOD: 150 DAY AFTER LPO ISSUE ON FOR UCH & KUNNER FIELDS.PAYMENT AFTER DELIVERY & INSPECTION AT SITES. DELIVERY OF ITEM NO.1-7 AT UCH GAS FIELD,BALOCHISTAN & ITEM NOS.8-13 AT KUNNER FIELD,SINDH.



**OIL & GAS DEVELOPMENT COMPANY LIMITED**  
**PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD**  
**SCHEDULE OF REQUIREMENT**

**Mandatory Checklist**

Please confirm the compliance of the following mandatory information along with the bid(s) (failing which bids(s) will not be accepted)

Documents	To be Attached with the Technical/Financial Bids	Compliance	
		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Original Bid Bond	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Copy of NTN Certificate	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Copy of GST Certificate	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Confirmation that the Firm is appearing on FBR's Active Taxpayer List	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly signed and stamped <b>Annexure-A (Un-priced)</b>	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped <b>Annexure-B</b>	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped <b>Annexure-D</b>	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped <b>Annexure-L</b> on Company's Letterhead	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly signed and stamped <b>Annexure-M</b> on Company's Letterhead	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly signed and stamped <b>Annexure-N</b> on Non-Judicial Stamp Paper duly attested by Notary Public	Technical Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped <b>Annexure-A (Priced)</b>	Financial Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped <b>Annexure-C</b>	Financial Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duly filled, signed and stamped <b>Annexure-E</b>	Financial Bid	Yes <input type="checkbox"/>	No <input type="checkbox"/>



**OIL & GAS DEVELOPMENT COMPANY LIMITED**  
**PROCUREMENT DEPARTMENT (LOCAL), ISLAMABAD**  
**SCHEDULE OF REQUIREMENT**

For the Vendors/Contractors who opt to submit Bank Draft/Call Deposit/Pay order against Bid Bond/Performance Bond, our Accounts Department has finalized an arrangement for online payment to such Vendors/Contractors, which will be processed through (IBFT & LFT) for which following information is required:

i.	IBAN No. (International Bank Account Number 24 Digits)	
ii.	Vendor Name as per Title of their Bank Account	
iii.	Contact No.of Company's CEO/ Owner (Mobile & Landline)	
iv.	Bank Name.	
v.	Bank Branch Name and Code	

Name, Sign and Stamp of the authorized official of the Bidder(s) \_\_\_\_\_

## **TECHNICAL TERMS & CONDITIONS:**

1. Bidder/Supplier shall be responsible for the compliance of **SOR**.
2. OEM Authority must be provided with the Technical bid.
3. Only genuine equipment should be quoted against the requirement, open market equipment are not acceptable.
4. Equipment must be new & free from any defect.
5. Equipment must be in original OEM Packing.
6. If bidder found any ambiguity in part nos. of required equipment, it should be cleared prior to bid opening date.
7. Equipment must have standard OEM warranty/guarantee.
8. Bidder/ Supplier shall be responsible to ensure the delivery of material within **150 days after issuance of LPO**.
9. Bidder/ Supplier shall be responsible for provision of **Complete Technical data, Literature** and other relevant documents in Hard Copies.
10. Copy of at least 3 POs for same type of material to be provided with the bid.
11. Bidders quoting equivalent equipment, must provide a certificate from 3 E&P companies stating that quoted equipment (equivalent equipment) are used by them and performance of such equipment is satisfactory.
12. Bidders quoting equivalent equipment, must provide certificate/evidence showing that the quoted product is certified to IEC 61508/SIL2/SIL3 and ATEX/IECEX.