



OIL AND GAS DEVELOPMENT COMPANY LIMITED
NASHPA OIL AND GAS FIELD

Date: 02-11-2022

SCHEDULE OF REQUIREMENT

TENDER ENQUIRY # NOF/INST/15/2022

Subject: Web Tender for Procurement of Miscellaneous Field Instrumentation for Membrane Unit of Wali Plant

S#	Description	Reference #	Rate	Total rate (inclusive of all Taxes)	Deviation
1	As per attached list				

Miscellaneous Field Instrumentation for Membrane Unit of Wali Plant			
S.NO.	Description	Quantity	Remarks
1.	I/P Converter mounted with Air supply regulator I/P convertor Specs: Input: 4-20mA, Output: 6-30PSI, Air supply pressure: 60 psi, Body/port Conn: ¼" NPTF, Mounting: 2" Pipe support. Mounting Bracket: Yes Gland entry: M20, Area: Hazardous Area Classification Make: Any Reputable Company	02 Nos	For Burner line TCVs up gradation.
2.	I/P Converter mounted with Air supply regulator I/P convertor Specs: Input: 4-20mA, Output: 3-15PSI, Air supply pressure: 20 psi, Mounting: 2" Pipe support. Mounting Bracket: Yes Body/port Conn: ¼" NPTF, Gland entry: M20, Area: Hazardous Area Classification Make: Any Reputable Company	01 Nos	For In/Out Gas line TCV
3.	SOV for Flare Ignition Panel Supply Volts: 220VAC, Type: 2 way, Depressurize position: N.C. Port Size: 1/2" NPTF, Fluid Type: Air, Gland Size entry: M20, Max Pressure: 130PSI, Area: Hazardous Area Classification Make: ASCO	02 Nos	For Flare System
4.	Vortex Cooler System for Control Panel Cooling Make: Any reputable company. UCP Dimensions: 6'x2.5'x1.5'	01 No	For Water Bath Heater UCP Up gradation
5.	M20 Cable glands with Shroud Explosion Proof Material: Brass Make: Any Reputable company	40 Nos	
6.	M25 Cable glands with Shroud Explosion Proof Material: Brass Make: Any Reputable company	20 Nos	

7.	M32 Cable glands with Shroud Explosion Proof Material: Brass Make: Any Reputable company	05	
----	----------------------------------------------------------------------------------------------------------	----	--

TERMS AND CONDITIONS:

1. The material will be delivered at Nashpa Oil Field, the delivery charges to Nashpa Oil Field be borne by the supplier/ bidder.
2. Maximum delivery time is 12 working weeks after issuance of Purchase Order.
3. In case of any technical clarification/details regarding material mentioned above, it must be cleared before submission of bid.
4. No change in substance of bid will be entertained after bid submission date.
5. Material Test Certificates and Calibration certificates to be provided.
6. Material will be accepted after final inspection, functional test and commissioning at site.
7. Payment will be made thereof by OGDCL Head Office upon acceptance of materials.
8. The firm must provide following documentation.
 - IBAN / Bank Account Details for online payment
 - NTN and GST numbers
 - Active status on FBR website
 - Professional Tax Certificate
 - Annex-C with Submitted Status
 - Sales Tax and Commercial Invoice
 - Goods Declaration Form

I/C Instrument